

ADDRESS : 61 STARLIGHT DR
CONTRACTOR :
OWNER : BUCHANAN JENNIFER D
PARCEL : 13-0610- - -0107- -27-
APPL NUMBER: 16-50040243 CP ADD & ALTER RESIDENTIAL

SUBDIV: NEW HORIZONS
PHONE :
PHONE :

DIRECTIONS : T/S: 11/28/2016 11:45 AM JBROCK ----
421 TOWARD SANFORD TURN R COOL SPRING
RD TURN R INTO NEW HORIZON S/D SECOND
HOUSE ON THE LEFT

LAND NOTES : LXMN 9/14/04 SPLIT FROM THE 10 PARCEL

STRUCTURE: 000 000 14X24 BDR&BATH GARAGE W/OUT PERMITS

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 SEPTIC - EXISTING? : EXT TANK
WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 01	12/22/16 12/22/16	TSG DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002913929 ① ALL RECPTICALS REQUIRED TO BE TAMPER RES. 2-ARC FAULT BREAKERS REQUIRED ③-WILL NEED TO VERIFY R RATING FOR INSULATION IN EXTERIOR WALLS, (R-15) 4-WINDOWS WILL BE REQUIRED TO MEET HEAT GAIN RATING. 5-FLOOR SYSTEM WILL HAVE TO BE INSPECTED. 6-FOUNDATION MIN VENTING REQUIRED. 7-FLOOR INSULATION MIN R-19. 8- ATTIC INSULATION MIN R-38 9-MECHNICAL CAPACITY CHECK REQUIRED.
R429 02	2/01/17	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002926996 T/S: 01/31/2017 09:40 AM JBROCK -----

[Handwritten signatures and initials over the table rows]

PERMIT: CPIR 00 CP INSULATION RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
I129 01	2/01/17	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002927614 T/S: 01/31/2017 02:52 PM DJOHNSON -----

[Handwritten signatures and initials over the table row]

COMMENTS AND NOTES

[Large handwritten notes and signatures in the bottom left corner]

[Handwritten signature or initials in the bottom right corner]



This home has been professionally insulated with

Owens Corning PROPINK® L77 PINK Fiberglas™ Unbonded Loosefill Insulation

(Job Site Address)

Name Jennifer Buchner
 Address 61 STATZGATE DR.
 City HILLINGTON State NC. Zip 27546

Owens Corning PROPINK® L77 PINK Fiberglas™ Unbonded Loosefill Insulation

Owens Corning will accept no responsibility when the product is not installed in accordance with the product label. Stated R-value is provided by installing the required number of bags at a thickness not less than the labeled minimum thickness. Installation of the required number of bags may yield more than the specified minimum thickness. Failure by the installer to provide both the required bags and at least the minimum thickness will result in lower insulation R-value.

Specification for Open Blow Attic

Specification	R-Value	Bags Per 1000 Sq. Ft.	Maximum Net Coverage	Minimum Weight/ Sq. Ft.	Minimum Thickness (in)	Maximum Settled Thickness
New Construction <input checked="" type="checkbox"/>	R-13	5.5	102.0	0.140	4.75	4.75
Retrofit	R-19	8.0	124.2	0.266	6.75	6.75
R-25	11.0	106.1	0.311	7.75	7.75	
Number of bags used	R-25	11.0	87.9	3.368	9.00	9.00
Estimated R-value of previous insulation	R-30	1.0	77.6	0.408	13.25	0.25
R-30	1.0	77.6	0.408	13.25	0.25	
R-34	20.1	49.8	0.662	14.75	14.75	
Area of coverage (sq. ft.)	R-49	22.2	44.2	0.747	16.25	16.25
R-60	25.5	35.1	0.946	19.50	19.50	
Other type(s) of insulation in attic						
Thickness of insulation						
Depth of previous insulation						

Floors

R-Value	Minimum Thickness	Installed Density (Lbs. Per Cu. Ft.)	Maximum Coverage Per Bag	Bags Per 1000 Sq. Ft.	Minimum weight (Lbs. Per Sq. Ft.)
R-13	2x8	1.1	19.0	25.6	0.876
R-19	2x10	1.4	30.6	31.7	1.079
R-25	2x12	1.6	23.5	42.6	1.165

Cathedral Ceiling

R-Value	Minimum Thickness	Installed Density (Lbs. Per Cu. Ft.)	Maximum Coverage Per Bag	Bags Per 1000 Sq. Ft.	Minimum weight (Lbs. Per Sq. Ft.)
R-13	2x8	1.3	42.0	2.38	0.783
R-19	2x10	1.3	37.9	30.4	1.002
R-25	2x12	1.3	27.0	36.9	1.219

This product shows negligible settling.

Loosefill insulations vary in thermal performance due to factors such as aging, mean temperature, settlement, convection, moisture absorption and installation variation. Convection in glass loosefill insulation installed in open attics can reduce its thermal performance in extreme winter temperatures during the heating season.

Blanket Insulation

Blanket and batt fiber glass insulation, when installed according to the manufacturers recommendations, will provide the stated R-Value. (R-18 in a 5.5" cavity)

R-VALUE	R-38	R-38C	R-30	R-30C	R-25	R-22	R-21	R-19	R-15	R-13	R-11
To obtain an insulation resistance (R) of:											
MINIMUM THICKNESS installed insulation should be:	12"	10.25"	9.5"	8.25"	6.0"	6.75"	5.5"	6.25"	3.5"	3.5"	3.5"

THE FOLLOWING PRODUCTS HAVE BEEN INSTALLED AS SPECIFIED ABOVE:

	Kraft	Unfaced	Foil	FS-25	R-Value	Thickness	No. pkgs.	Coverage Area
Ceiling	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	R-38 (Blown)	12 3/4"	6	336 sq ft
Floors	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	R-19	4 1/4"	4	336 sq ft
Walls	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	R-13 (Blown)	3 1/2"	5	416 sq ft
Basement	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				
Crawlspace	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				

Contractor A. J. Clark Jr. Date 1/13/2017 Builder _____ Date _____

Company _____ Company _____

Address _____ Address _____

Phone _____ Phone _____



OWENS CORNING INSULATING SYSTEMS, LLC