## HARNETT COUNTY HEALTH DEPARTMENT ENVIRONMENTAL HEALTH 307 CORNELIUS HARNETT BOULEVARD LILLINGTON, NC 27546

## **EXISTING SEPTIC SYSTEM INSPECTION**

Name: Robert Lawrenz

Phone #: 804-441-4788

Address: 30 Macon Ct E. Sanfod NC 27332

Name of Mobile Home Park or S/D: Highlan Forest lot 106

Name of Owner (if different): \_\_\_\_\_

Address of Owner (if different):

Property Location (State Road name and #): <u>30 Macon Ct E</u>

Purpose of Inspection: Deck (11'x24')

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

## THIS INSPECTION IS VOID IF:

- 1. the intended use of the septic system should change, and/or
- 2. the system should fail or malfunction, and/or
- 3. the owner or tenant of the property change, and/or
- 4. after six months

## BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM DO NOT DRIVE OR PARK ON SEPTIC SYSTEM

aroso

AUTHORIZATION OF EXISTING SYSTEM

Signature of Environmental Health Specialist