

HTE# 17-5-40706

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Tant Custom Homes IDC PHONE # 919-669-1818

ADDRESS 359 Truth Rd New Hill N.C. 27562

NAME OF MOBILE HOME PARK OR S/D Taylor Point lot 5

NAME OF OWNER (IF DIFFERENT) Patrick + Lynn Welton

ADDRESS OF OWNER (IF DIFFERENT) 60 Yelverton Ct A.C. N.C. 27540

PROPERTY LOCATION: STATE ROAD NAME AND # SR 1452 Travelers Rd

PURPOSE OF INSPECTION: 20x20 Garage Roof Core Sab

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Markham  
Signature of Environmental Health Specialist

3-7-17  
Date