

-----

ADDRESS . . : 142 D'ANGO CIR  
 CONTRACTOR :  
 OWNER . . : AVILA PABLO ALBERTO & ANGULA  
 PARCEL . . : 04-0662- - -0015- -12-  
 APPL NUMBER: 17-50041100 CP ADD & ALTER RESIDENTIAL  
 DIRECTIONS : T/S: 04/05/2017 11:54 AM LBENNETT --  
 142 D ANGO CIRCLE - PEAR MEADOW LOT#9  
 ANGIER

SUBDIV: PEAR MEADOWS 28LOTS  
 PHONE :  
 PHONE :

-----

**STRUCTURE: 000 000 FINISH BONUS ROOM**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 SEPTIC - EXISTING? . . . . : EXIST  
 WATER SUPPLY . . . . . : COUNTY

-----

**PERMIT: CPBP 00 CP BUILDING PERMIT**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R225 01	7/20/17 7/20/17	BS DA	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 002999738 T/S: 07/18/2017 02:47 PM JBROCK ----- T/S: July 20, 2017 01:35 PM BSUTTON ----- Fireblock and firecaulk gables, and holes in top plates around door. 2. Need insulation baffles in place at rough in
R225 02	7/26/17 7/26/17	BS AP	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 003003282 T/S: 07/25/2017 12:16 PM LLUCAS ----- T/S: July 26, 2017 04:19 PM BSUTTON -----
R229 01	6/06/18 <u>11</u>	TI <u>AP</u>	TWO TRADE FINAL TIME: 17:00 VRU #: 003135258 T/S: 06/04/2018 11:21 AM BPETRICH ----- AM INSPECTION REQUESTED - H/O WORKING FROM HOME AND HAS MEETING AT LUNCH.

----- COMMENTS AND NOTES -----