

May 17, 2017

J.A. Hart Construction
3483 Cameron Dr
Sanford, NC 27332

RE: Existing Septic System Inspection HTE# 17-5-41301


To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an Existing Tank Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal (**\$25.00 fee incurred**)
- 2. Have system pumped out
- 3. Replace sanitary T
- 4. Other – **Call to set up an onsite meeting with a backhoe for pits. Current system sized for 2 bedroom home.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Oliver Tolksdorf, R.E.H.S.
Environmental Health OSWW Soil Scientist
Harnett County Department of Public Health
Environmental Health

OT/kh
Copy - Central Permitting