

HTE# 17-5-41571

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Black River Wood Work PHONE # 919-757-4539
ADDRESS 574 N Broad St E Angier N.C. 27501
NAME OF MOBILE HOME PARK OR S/D Alex Place
NAME OF OWNER (IF DIFFERENT) Kenneth Wanda Jr
ADDRESS OF OWNER (IF DIFFERENT) MS Tannett Bay Ln F.V. N.C. 27526
PROPERTY LOCATION: STATE ROAD NAME AND # SR 1415 North Cornwall Rd

PURPOSE OF INSPECTION: 17x19 Deek Expansion

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Markant
Signature of Environmental Health Specialist

6-19-17
Date