

HTE #: 17-5-42624

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: David Carroll Homes Inc Phone #: 919-669-7999

Address: 1904 Phelps West Road Fuquay-Varina, NC 27526

Name of Mobile Home Park or S/D: Victoria Hills Lot 15

Name of Owner (if different): Ryan and Jocelyn Midgett

Address of Owner (if different): 24 Elmbrook Ct. Fuquay-Varina, NC 27526

Property Location (State Road name and #): Lafayette Road (SR 1443)

Purpose of Inspection: Addition - Flexroom and Study (11' 8"x 36'). No bathroom. No bedrooms. Proposed addition not within septic field, repair area, or septic setbacks.

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

11/06/2017
Date