

February 1, 2018

ph: 910-893-7547

fax: 910-893-9371

Dale Morgan
2594 Old Fairground Rd
Angier, NC 27501

RE: Existing Tank Application HTE# 18-5-43132

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover Outlet lid on septic tank and break seal (\$25.00 fee incurred)
- 2. Have system pumped out
- 3. Replace sanitary T
- 4. **Other – Any addition to be 5' from septic tank and/or from drain line.**

Your application will be put on hold until the selected items above have been addressed.

When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E. Manhart III, R.E.H.S
Environmental Health Program Specialist
Harnett County Department of Public Health
Environmental Health

JM/kh

Copy - Central Permitting