



Harnett County
 420 McKinney Pkwy
 LILLINGTON, NC 27546
 Phone:
 Fax:

9/12/2023

**SUBJECT: CARE18-50043882
 BUILDING RESIDENTIAL**

To: LIRA RUBEN

Here are the results of all Inspections located at **75 CURRIE DR:**

Inspection Type: FINAL**
 Scheduled Date/Time:
 Completed Date/Time:
 Inspector: Ray Holder
 Result:
 Remarks:
 Notes:

Inspection Type: TWO TRADE ROUGH IN
 Scheduled Date/Time: 5/1/2018
 Completed Date/Time: 5/1/2018
 Inspector: Unassigned
 Result: DISAPPROVED
 Remarks:
 Notes:

T/S: 04/30/2018 03:39 PM LLUCAS ----- JIMMY PLEASE BE THERE AT 8:00 AM TO MEET CUSTOMER

1)Need access to all junction boxes in ceiling.2)All electrical that has been replace needs to meet the current code.3)Need engineer letter for repairs in master bathroom roof, back addition added without permits & attached to home & any changes to plumbing,electrical, framing & mechanical.4)Need smoke & carbon detectors per code.

Inspection Type: FINAL**
 Scheduled Date/Time: 6/26/2019
 Completed Date/Time: 6/26/2019
 Inspector: Scott Guy
 Result: DISAPPROVED
 Remarks:
 Notes:

Inspector RLH changed the inspection assignment from RLH to TSG
 Home must be habitable, complete repairs ,set sinks , toilets, and close up outsides of home from weather. 2- all electrical must be safe and secured, covers and plates.

