

HTE #: 18-5-43895

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Southeastern Construction of Buies Creek Phone #: 919.282.2443

Address: P.O. Box 157 Buies Creek, NC 27506

Name of Mobile Home Park or S/D: Benton Place Lot 16

Name of Owner (if different): Abonza Luis Fernando Rosales

Address of Owner (if different): 270 Benton Place Drive Angier, NC 27501

Property Location (State Road name and #): Lipscomb Road (SR 1504)

Purpose of Inspection: Addition - Attached Garage (24'x26'). No additional bedrooms. Proposed addition not within septic field, septic setbacks, or repair area.

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

05/14/2018

Date