

**MARSHALL ENGINEERING SERVICES, PLLC**  
7575 McArtans Ford  
Linden, NC 28356  
(910) 850 5874  
Corp. License P-0682  
Randolph@RandolphMarshall.com

Action Electrical & HVAC Repair  
Attn: Steve Bullock  
P.O. Box 1497  
Fayetteville, NC 28356

December 5, 2018

Subject: 146 Shellbark Drive  
Spring Lake, NC


I inspected the trusses in the attic at the above address to determine if the installed electrical wires effected the structural integrity of the truss members.

The  $\frac{3}{4}$ "-1" do not measurably degrade the strength of the 2x6 vertical members.

I have no structural concerns regarding the installation of the electrical wiring.

Sincerely,

  
E. Randolph Marshall



5 Dec. 2018