

June 19, 2018

Jose Cuellar  
627 Chinaberry Lane  
Angier, NC 27501

ph: 910-893-7547  
fax: 910-893-9371

**RE: Harnett County Land Use Existing Tank Application # 18-5-44209**

Dear Mr. Cuellar,

The Harnett County Department of Public Health, Environmental Health Division evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting a 15 x 33 family room addition and a deck addition of 12 x 20. The evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules. *Please note that your septic tank lid was not uncovered and the seal broken at the time of the visit and an additional \$25.00 will be incurred for the return visit as well as a possible revision fee should you change your site plan.*

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

- 15A NCAC 18A.1950a {16} - Any swimming pool must be 15' from any part of septic system.**
- 15A NCAC 18.1945{b} - Each lot shall have original septic system plus repair area.**
- 15A NCAC 18A.1950 {10} - Any building to be 5' from septic tank and/or from drain line. (This pertains to the proposed deck)**
- 15A NCAC 18A.1950{c} - Nitrification fields and repair areas shall not be located under paved areas or areas subject to vehicular traffic.**

Call me to discuss further the options that may be available to you. If you should have any questions or concerns, I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,



Andrew Currin, R.E.H.S.  
Environmental Health OSWW Specialist  
Harnett County Department of Public Health

AC/sgs