

HTE #: 18-5-44277R

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Robco Fence and Deck

Phone #: 919.390.0296

Address: 1521 Gavin Street Raleigh, NC 27608

Name of Mobile Home Park or S/D: Olive Branch S/D Lot 2

Name of Owner (if different): Charles Dixon

Address of Owner (if different): 43 Hamilton Farm Circle Fuquay-Varina, NC 27526

Property Location (State Road name and #): 43 Hamilton Farm Circle (Kipling Road - SR 1403)

Purpose of Inspection: Wood Deck (18'x14') - Above ground pool and wood deck (18'x14') located in permitted gravity septic repair area. Pump to repair may be required and/or above ground pool/deck removed in event of repair.

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM


Signature of Environmental Health Specialist

07/06/2018

Date