



Plan Review, Inspection and Permit Fees

Application Number 08 -- 50019777

\$100.00	_____	Explosive Materials (90 Days)
\$ 35.00	_____	Explosive Materials (48 Hrs)
\$ 25.00	_____	Fireworks Public Display
\$ 20.00	<u>1</u>	Final Inspection
\$ 25.00	_____	Fire Alarm Testing
\$ 25.00	_____	Fixed Fire Suppression
\$ 10.00	_____	Insecticide Fog/Fumigation
\$ 50.00	_____	Testing of Pipes/UST/AGST
\$ 50.00	_____	Plans up to 5000 ft ²
\$100.00	<u>1</u>	Plans 5001 ft ² to 10,000 ft ²
\$150.00	_____	Plans 10,001 ft ² to 25,000 ft ²
\$250.00	_____	Plans 25,001 ft ² and over
\$ 25.00	_____	Sprinkler Certification Test
\$ 25.00	_____	Standpipe Testing
\$ 25.00	_____	Special Assembly
\$ 10.00	_____	Temporary Kiosks/Displays
\$ 10.00	_____	Tents greater than 700 ft ²
\$ 50.00	_____	Tank Installation (charge for each tank)
\$ 50.00	_____	Tank Removal (charge for each tank)

\$ 120.⁰⁰/₄ Total



 Code Enforcement Official

5-16-08

 Date

Fire Marshal/Emergency Management

Mailing: P. O. Box 370 Lillington, NC 27546
Physical: 200 North 13th Street, Suite 19
Erwin, NC 28339

910-893-7580
910-893-5025

APPLICATION FOR PLAN REVIEW

APPLICATION NUMBER: 085-0019777

TODAY'S DATE: 4-21-08 RECEIVED BY: [Signature]

SUBMITTED BY: Steve Thomas

NAME OF PROJECT: MT. Pisgah Presbyterian Church

PHYSICAL ADDRESS: 2300 MT Pisgah Church Rd. Broadway 27505

PHONE NUMBER: 919-906-4069 EXT.: _____

CONTACT PERSON: Steve Thomas

MAILING ADDRESS: PO Box 875 Broadway NC 27505

PHONE NUMBER: 919-906-4069

CONTRACTOR'S NAME: Taylor's Construction

MAILING ADDRESS: 179 Rosser Pittman Rd. Broadway NC 27505

PHONE NUMBER: _____

NOTICE

PLANS THAT ARE SUBMITTED WILL BE REVIEWED AS QUICKLY AS POSSIBLE, WITH AN AVERAGE TIME OF REVIEW BETWEEN 7 - 10 WORKING DAYS.



Harnett
C O U N T Y
NORTH CAROLINA



Emergency Services Department

www.harnett.org

200 N. 13th Street
Suite 19
Erwin, NC 28339

Mailing Address:
PO Box 370
Lillington, NC 27546

ph: 910-893-7580
fax: 910-893-5025

May 16, 2008

Steve Thomas
Post Office Box 875
Broadway, NC 27505

Mt. Pisgah Presbyterian Church
2300 Mt. Pisgah Church Road
Broadway, NC 27505

Application Number 08-50019777

Mr. Thomas,

Thank you for submitting the plans for the new fellowship hall. The plans have been carefully reviewed by a qualified code enforcement official to examine for full compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **906.1 Fire Extinguishers**
 - Fire extinguishers shall be placed in approved locations as drawn by the code enforcement official on the approved plans.
 - The fire extinguishers provided shall have a minimum rating of 2A 10B: C and shall not be installed higher than 5 feet above the finished floor.
- **Fire Department Access**
 - The fire department access shall extend to within 150 feet of all portions of the facility.
 - The fire department access road shall be of an unobstructed width of not less than 20 feet and shall have an unobstructed vertical clearance of not less the 13 feet 6 inches.

- **506.1 Knox Box**

- A secure key box shall be installed on the new building that houses all keys to all the doors within the building in which the fire department would need access to in the event of an emergency.
- Knox Box ID stickers shall be placed on all exterior doors in which entry to the building may be gained.
- The box shall be mounted not to exceed 48 – 60 inches in height.
- An authorized order form is included with this letter (Choose any of the 3200 Series listed on the back of the order form).

- **1016.1 Corridors**

- The side corridor (alcove) is serving an occupant load greater than 30 and is in an unsprinkled building.
- The corridor shall be rated at no less than a 1-hour fire resistance rating. The walls already have a rating. The ceiling needs to be rated.

703.1 Maintenance of Fire Assemblies

- The required fire-resistance rating of fire-resistance-rated construction (including walls, fire stops, shaft enclosures, partitions and floors) shall be maintained. Such elements shall be properly repaired, restored or replaced when damaged, altered, breached or penetrated. Openings made therein for the passage of pipes, electrical conduit, wires, ducts, air transfer openings, and holes made for any reason shall be protected with approved methods capable of resisting the passage of smoke and fire. Openings through fire-resistance-rated assemblies shall be protected by self-closing or automatic-closing doors of approved construction meeting the fire protection requirements for the assembly
- Future penetrations to be sealed with some type of removable fire stop

- **505.1 Physical Address**

- The physical address of the building shall be posted in a conspicuous place so that it can be seen on approach from the road, access road, and/or parking lot.
- The numbers used to make up the physical address shall be at least 5 inches in height.

- **Duct Detectors**

- Duct Detectors shall be mounted as shown on the plans.
- Each Detector shall have an audio/visual device acknowledging activation as noted on the plans

- **1004.1.2 Occupancy Load**

- The occupancy load for the building must be posted at the time of the final inspection. The Fire Marshal's Office will provide the posting documents.

Thank you again for submitting the plans for the new fellowship hall. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office

Again, thank you and we look forward to working with you during the construction period!

Sincerely,



Michael L. Martin
Deputy Fire Marshal