

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

D/ _____

FACTORS		PROFILES												
		1	2	3	4	5	6	7	8	9	10			
LANDSCAPE POSITION	.1940													
SLOPE (%)	.1940													
HORIZON 1 DEPTH		0"	0"	0"	0-26"	0-18"	0-24"							
Texture Group	.1941(A)(1)	Pm	Pm	Pm	LS	SL	SL							
Consistence	.1941				VRZ									
Structure	.1941(A)(2)				G									
Mineralogy	.1941(A)(3)				whp									
HORIZON 2 DEPTH					26"-34"	18-32"	24-38"							
Texture Group	.1941(A)(1)				SL	SCL	SCL							
Consistence	.1941				FR									
Structure	.1941(A)(2)				G									
Mineralogy	.1941(A)(3)				SS/np									
HORIZON 3 DEPTH														
Texture Group	.1941(A)(1)													
Consistence	.1941													
Structure	.1941(A)(2)													
Mineralogy	.1941(A)(3)													
HORIZON 4 DEPTH														
Texture Group	.1941(A)(1)													
Consistence	.1941													
Structure	.1941(A)(2)													
Mineralogy	.1941(A)(3)													
SOIL WETNESS	.1942				30"	36"	30"							
RESTRICTIVE HORIZON	.1944													
SAPROLITE	.1943/.1956													
CLASSIFICATION	.1948	U3	U3	U3	P3	P3	P3							
LONG TERM ACCEPTANCE RATE	.1955				.6	.5	.5							

* 1 - EXCESSIVE @ 20"

2x50' @ 18" 1000gal tank

