

-----  
ADDRESS . : 17288 \*UNASSIGNED SUBDIV:  
CONTRACTOR : BIM BUILDERS LLC PHONE : (919) 894-5741  
OWNER . . : ENNIS GARY M & PATTY S PHONE : (919) 207-1952  
PARCEL . . : 02-1518- - -0275- - -  
APPL NUMBER: 07-50017136 CP GARAGE/CARPORT RESIDENTIAL DETACHED  
DIRECTIONS : 421 THROUGH BUIES CREEK LEFT ON 27 TAKE  
27 THROUGH COATS TRUN RIGHT ON  
FAIRGROUND RD 3/4 MILE ON RIGHT LOT 1  
JB

LAND NOTES : LXMN 3/29/07 split 2.374ac o/o 02-1526-0100 and  
combined with this parcel. split  
.0397aco/o this parcel and combined  
with 01 parcel tj

-----  
STRUCTURE: 000 000 24X40 2 BAY GARAGE W/ FULL BATH  
FLOOD ZONE . . . . : FLOOD ZONE X

-----  
PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07 <u>4-10</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001386100 <u>LS</u>

----- COMMENTS AND NOTES -----

-----

ADDRESS . : 17288 \*UNASSIGNED SUBDIV:  
 CONTRACTOR : BIM BUILDERS LLC PHONE : (919) 894-5741  
 OWNER . . : ENNIS GARY M & PATTY S PHONE : (919) 207-1952  
 PARCEL . . : 02-1518- - -0275- - -  
 APPL NUMBER: 07-50017136 CP GARAGE/CARPORT RESIDENTIAL DETACHED  
 DIRECTIONS : 421 THROUGH BUIES CREEK LEFT ON 27 TAKE  
 27 THROUGH COATS TRUN RIGHT ON  
 FAIRGROUND RD 3/4 MILE ON RIGHT LOT 1

JB  
 LAND NOTES : LXMN 3/29/07 split 2.374ac o/o 02-1526-0100 and  
 combined with this parcel. split  
 .0397aco/o this parcel and combined  
 with 01 parcel tj

-----

STRUCTURE: 000 000 24X40 2 BAY GARAGE W/ FULL BATH  
 FLOOD ZONE . . . . : FLOOD ZONE X

-----

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001386100
	4/11/07	AP	
B103 01	4/19/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001392683

4-19 AP

KS

-----  
 COMMENTS AND NOTES  
 -----

-----  
ADDRESS : 2576 FAIRGROUND RD SUBDIV:  
CONTRACTOR : BIM BUILDERS LLC PHONE : (919) 894-5741  
OWNER : ENNIS GARY M & PATTY S PHONE : (919) 207-1952  
PARCEL : 02-1518- - -0275- - -  
APPL NUMBER: 07-50017136 CP GARAGE/CARPORT RESIDENTIAL DETACHED  
DIRECTIONS : 421 THROUGH BUIES CREEK LEFT ON 27 TAKE  
27 THROUGH COATS TRUN RIGHT ON  
FAIRGROUND RD 3/4 MILE ON RIGHT LOT 1

JB  
LAND NOTES : LXMN 3/29/07 split 2.374ac o/o 02-1526-0100 and  
combined with this parcel. split  
.0397aco/o this parcel and combined  
with 01 parcel tj

-----  
STRUCTURE: 000 000 24X40 2 BAY GARAGE W/ FULL BATH  
FLOOD ZONE . . . : FLOOD ZONE X

-----  
PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07 4/11/07	FS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001386100
B103 01	4/19/07 4/19/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001392683
B105 01	4/24/07 <u>4-24</u>	TI <u>AP</u>	R*OPEN FLOOR VRU #: 001395387

KS

-----  
COMMENTS AND NOTES  
-----

-----  
ADDRESS . : 2568 FAIRGROUND RD SUBDIV:  
CONTRACTOR : BIM BUILDERS LLC PHONE : (919) 894-5741  
OWNER . . : ENNIS GARY M & PATTY S PHONE : (919) 207-1952  
PARCEL . . : 02-1518- - -0275- - -  
APPL NUMBER: 07-50017136 CP GARAGE/CARPORT RESIDENTIAL DETACHED  
DIRECTIONS : 421 THROUGH BUIES CREEK LEFT ON 27 TAKE  
27 THROUGH COATS TRUN RIGHT ON  
FAIRGROUND RD 3/4 MILE ON RIGHT LOT 1  
JB

LAND NOTES : LXMN 3/29/07 split 2.374ac o/o 02-1526-0100 and  
combined with this parcel. split  
.0397aco/o this parcel and combined  
with 01 parcel tj

-----  
STRUCTURE: 000 000 24X40 2 BAY GARAGE W/ FULL BATH  
FLOOD ZONE . . . : FLOOD ZONE X

-----  
PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001386100
	4/11/07	AP	
B103 01	4/19/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001392683
	4/19/07	AP	
B105 01	4/24/07	KS	R*OPEN FLOOR VRU #: 001395387
	4/24/07	AP	
B111 01	5/09/07	TI	R*BLDG SLAB INSP VRU #: 001406040

5-9- AP

----- COMMENTS AND NOTES -----

-----  
ADDRESS . : 2568 FAIRGROUND RD SUBDIV:  
CONTRACTOR : BIM BUILDERS LLC PHONE : (919) 894-5741  
OWNER . . : ENNIS GARY M & PATTY S PHONE : (919) 207-1952  
PARCEL . . : 02-1518- - -0275- - -  
APPL NUMBER: 07-50017136 CP GARAGE/CARPORT RESIDENTIAL DETACHED  
-----

DIRECTIONS : 421 THROUGH BUIES CREEK LEFT ON 27 TAKE  
27 THROUGH COATS TRUN RIGHT ON  
FAIRGROUND RD 3/4 MILE ON RIGHT LOT 1  
JB

LAND NOTES : LXMN 3/29/07 split 2.374ac o/o 02-1526-0100 and  
combined with this parcel. split  
.0397aco/o this parcel and combined  
with 01 parcel tj

-----  
STRUCTURE: 000 000 24X40 2 BAY GARAGE W/ FULL BATH  
FLOOD ZONE . . . : FLOOD ZONE X  
-----

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07 4/11/07	FS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001386100
B103 01	4/19/07 4/19/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001392683
B105 01	4/24/07 4/24/07	KS AP	R*OPEN FLOOR VRU #: 001395387
B111 01	5/09/07 5/09/07	KS AP	R*BLDG SLAB INSP VRU #: 001406040
R125 01	6/08/07 6/07/07	TI CA	ONE TRADE ROUGH IN VRU #: 001425238
R425 01	6/08/07	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001426162

6-8 ~~AP~~ DA

----- COMMENTS AND NOTES -----

**Violation Notice  
Do Not Remove**

**Harnett County Inspection Department  
102 East Front St P.O. Box 65  
Lillington, NC 27546  
Phone (910) 893-4876 Fax (910) 893-2793**

App # 07-50017136

1. Need flashing for weep holes for brick veneer.
2. Need to remove ducts from garage or install fire dampers.
3. Ok to insulate and side.

Code Enforcement Official

Signature Ken Slattum

-----  
ADDRESS : 2568 FAIRGROUND RD SUBDIV:  
CONTRACTOR : BIM BUILDERS LLC PHONE : (919) 894-5741  
OWNER : ENNIS GARY M & PATTY S PHONE : (919) 207-1952  
PARCEL : 02-1518- - -0275- - -  
APPL NUMBER: 07-50017136 CP GARAGE/CARPORT RESIDENTIAL DETACHED  
-----

DIRECTIONS : 421 THROUGH BUIES CREEK LEFT ON 27 TAKE  
27 THROUGH COATS TRUN RIGHT ON  
FAIRGROUND RD 3/4 MILE ON RIGHT LOT 1  
JB

LAND NOTES : LXMN 3/29/07 split 2.374ac o/o 02-1526-0100 and  
combined with this parcel. split  
.0397aco/o this parcel and combined  
with 01 parcel tj

-----  
STRUCTURE: 000 000 24X40 2 BAY GARAGE W/ FULL BATH  
FLOOD ZONE . . . : FLOOD ZONE X  
-----

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001386100
	4/11/07	AP	
B103 01	4/19/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001392683
	4/19/07	AP	
B105 01	4/24/07	KS	R*OPEN FLOOR VRU #: 001395387
	4/24/07	AP	
B111 01	5/09/07	KS	R*BLDG SLAB INSP VRU #: 001406040
	5/09/07	AP	
R125 01	6/08/07	TI	ONE TRADE ROUGH IN VRU #: 001425238
	6/07/07	CA	
R425 01	6/08/07	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001426162
	6/10/07	DA	1. Need flashing for weep holes. 2. Need to remove ducts from garage or install fire dampers. OK to side and insulate.
I129 01	6/18/07	TI	R*INSULATION INSPECTION VRU #: 001429528
	6/18/07	CA	
R425 02	6/18/07	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001430768
	6/18/07	CA	
R425 03	6/19/07	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001431782
	6-19	<del>AP</del> AP	

-----  
PERMIT: CPIR 00 CP INSULATION RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
I129 01	6/19/07	TI	R*INSULATION INSPECTION VRU #: 001430810
	6-19	AP	

----- COMMENTS AND NOTES -----

-----

ADDRESS . : 2568 FAIRGROUND RD SUBDIV:  
 CONTRACTOR : BIM BUILDERS LLC PHONE : (919) 894-5741  
 OWNER . . : ENNIS GARY M & PATTY S PHONE : (919) 207-1952  
 PARCEL . . : 02-1518- - -0275- - -  
 APPL NUMBER: 07-50017136 CP GARAGE/CARPORT RESIDENTIAL DETACHED  
 DIRECTIONS : 421 THROUGH BUIES CREEK LEFT ON 27 TAKE  
 27 THROUGH COATS TRUN RIGHT ON  
 FAIRGROUND RD 3/4 MILE ON RIGHT LOT 1  
 JB  
 LAND NOTES : LXMN 3/29/07 split 2.374ac o/o 02-1526-0100 and  
 combined with this parcel. split  
 .0397aco/o this parcel and combined  
 with 01 parcel tj

-----

STRUCTURE: 000 000 24X40 2 BAY GARAGE W/ FULL BATH  
 FLOOD ZONE . . . . : FLOOD ZONE X

-----

PERMIT: CP1R 00 CP INSULATION RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
I129 01	6/19/07 <u>6-19</u>	TI <u>AT</u>	R*INSULATION INSPECTION VRU #: 001430810 <u>KS</u>

----- COMMENTS AND NOTES -----

*B-8-*



-----  
ADDRESS . : 2568 FAIRGROUND RD SUBDIV:  
CONTRACTOR : BIM BUILDERS LLC PHONE : (919) 894-5741  
OWNER . . : ENNIS GARY M & PATTY S PHONE : (919) 207-1952  
PARCEL . . : 02-1518- - -0275- - -  
APPL NUMBER: 07-50017136 CP GARAGE/CARPORT RESIDENTIAL DETACHED  
DIRECTIONS : 421 THROUGH BUIES CREEK LEFT ON 27 TAKE  
27 THROUGH COATS TRUN RIGHT ON  
FAIRGROUND RD 3/4 MILE ON RIGHT LOT 1  
JB

LAND NOTES : LXMN 3/29/07 split 2.374ac o/o 02-1526-0100 and  
combined with this parcel. split  
.0397aco/o this parcel and combined  
with 01 parcel tj

-----  
STRUCTURE: 000 000 24X40 2 BAY GARAGE W/ FULL BATH  
FLOOD ZONE . . . . : FLOOD ZONE X

-----  
PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001386100
	4/11/07	AP	
B103 01	4/19/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001392683
	4/19/07	AP	
B105 01	4/24/07	KS	R*OPEN FLOOR VRU #: 001395387
	4/24/07	AP	
B111 01	5/09/07	KS	R*BLDG SLAB INSP VRU #: 001406040
	5/09/07	AP	
R125 01	6/08/07	TI	ONE TRADE ROUGH IN VRU #: 001425238
	6/07/07	CA	
R425 01	6/08/07	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001426162
	6/10/07	DA	1. Need flashing for weep holes. 2. Need to remove ducts from garage or install fire dampers. OK to side and insulate.
I129 01	6/18/07	TI	R*INSULATION INSPECTION VRU #: 001429528
	6/18/07	CA	
R425 02	6/18/07	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001430768
	6/18/07	CA	
R425 03	6/19/07	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001431782
	6/19/07	AP	
H824 01	8/03/07	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001460419
	8/03/07	AP	
R131 01	8/24/07	TI	ONE TRADE FINAL VRU #: 001473364

8.24 DP

-----  
COMMENTS AND NOTES  
-----

**Violation Notice**  
**Do Not Remove**

**Harnett County Inspection Department**  
**102 East Front St P.O. Box 65**  
**Lillington, NC 27546**  
**Phone (910) 893-4876 Fax (910) 893-2793**

App #07-50017136

1. Stairs shall not have open risers and shall have hand rail.
  2. Close guard rail at top of stairs.
  3. Need positive drainage around house and garage.
- \$50.00 re-inspection fee.

Code Enforcement Official

Signature Ken Slattum

ADDRESS : 2568 FAIRGROUND RD  
 CONTRACTOR : BIM BUILDERS LLC  
 OWNER : ENNIS GARY M & PATLY S  
 PARCEL : 02-1518- - -0275- -  
 APPL NUMBER: 07-50017136 CP GARAGE/CARPORT RESIDENTIAL DETACHED  
 DIRECTIONS : 421 THROUGH BUJES CREEK LEFT ON 27 TAKE  
 27 THROUGH COATS TRUN RIGHT ON  
 FAIRGROUND RD 3/4 MILE ON RIGHT LOT 1  
 JB  
 LAND NOTES : LXMN 3/29/07 split 2.374ac o/o 02-1526-0100 and  
 combined with this parcel. split  
 .0397aco/o this parcel and combined  
 with 01 parcel tj

STRUCTURE: 000 000 24X40 2 BAY GARAGE W/ FULL BATH  
 FLOOD ZONE . . . : FLOOD ZONE X  
 PERMIT: CBPP 00 CP BUILDING PERMIT

PERMITTED	REQUESTED	INSP	DESCRIPTION	RESULT	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	4/10/07	FS	R*BLDG FOOTING / TEMP SVC POLE	VRU # : 001386100			
B103 01	4/19/07	KS	R*BLDG FOUND & TEMP SVC POLE	VRU # : 001392683			
B105 01	4/24/07	KS	R*OPEN FLOOR	VRU # : 001395387			
B111 01	5/09/07	KS	R*BLDG SLAB INSP	VRU # : 001406040			
R125 01	6/08/07	TI	ONE TRADE ROUGH IN	VRU # : 001425238			
R425 01	6/08/07	KS	FOUR TRADE ROUGH IN	VRU # : 001426162			
	6/10/07	DA	1. Need flashing for weep holes. 2. Need to remove ducts from garage or install fire dampers.				
I129 01	6/18/07	TI	R*INSULATION INSPECTION	VRU # : 001429528			
R425 02	6/18/07	TI	FOUR TRADE ROUGH IN	VRU # : 001430768			
R425 03	6/19/07	KS	FOUR TRADE ROUGH IN	VRU # : 001431782			
H824 01	8/03/07	JM	ENVIR. OPERATIONS PERMIT	VRU # : 001460419			
R131 01	8/24/07	KS	ONE TRADE FINAL	VRU # : 001473364			
	8/24/07	DP	1. Stairs shall not have open risers and shall have hand rail. 2. Close guard rail at top of stairs. 3. Need positive drainage around house and garage.				
R429 01	8/29/07	TI	FOUR TRADE FINAL	VRU # : 001476076			

COMMENTS AND NOTES

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential  
Type of Construction: V  
Owner of Building: Gary Curcio  
Building Address: \_\_\_\_\_  
Zoning District: \_\_\_\_\_  
Zoning Permit No.: \_\_\_\_\_

Date: 8-29-07

Building Official

Conditional Use Permit No.: \_\_\_\_\_  
Building Permit No.: 114  
Electrical Permit No.: \_\_\_\_\_  
Insulation Permit No.: h  
Plumbing Permit No.: \_\_\_\_\_  
Mech. Permit No.: A  
Envir. C.O. No.: 0

Zoning Official