

HTE# 10-5-25588

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME TODD Whetten PHONE # 919-427-8465

ADDRESS 863 NEIGHBORS RD DUNN N.C. 28334

NAME OF MOBILE HOME PARK OR S/D _____

NAME OF OWNER (IF DIFFERENT) RONALD JENKINS

ADDRESS OF OWNER (IF DIFFERENT) P.O. BOX 655 COATS N.C. 27521

PROPERTY LOCATION: STATE ROAD NAME AND # SR 1769 CAMEL HILL RD

PURPOSE OF INSPECTION: GARAGE / STORAGE

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM

AUTHORIZATION OF EXISTING SYSTEM

James E. Manhart @ RBUS
Signature of Environmental Health Specialist

11-18-10
Date