

HTE# 12-5-29398

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Carolina Custom Builders PHONE # 919-790-1234

ADDRESS 4905 Depature Dr Raleigh N.C. 27616

NAME OF MOBILE HOME PARK OR S/D _____

NAME OF OWNER (IF DIFFERENT) Hambley & Roth Frame

ADDRESS OF OWNER (IF DIFFERENT) 1296 Young Rd Angier N.C. 27501

PROPERTY LOCATION: STATE ROAD NAME AND # SR 1546 Young Rd
28K54

PURPOSE OF INSPECTION: Garage / Storage

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Montfort
Signature of Environmental Health Specialist

8-8-12
Date