

HTE# 15-5-36769RR

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME JONATHAN A SANCHEZ PHONE # 919 271-7924

ADDRESS 87 Gary Dr Angier N.C. 27501

NAME OF MOBILE HOME PARK OR S/D KINNIS CREEK lot 36

NAME OF OWNER (IF DIFFERENT) _____

ADDRESS OF OWNER (IF DIFFERENT) _____

PROPERTY LOCATION: STATE ROAD NAME AND # OR 1440 James NORRIS

PURPOSE OF INSPECTION: 24x28 Detached Garage

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Manton
Signature of Environmental Health Specialist

10-7-15
Date