

HTE# 16-5-38013

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Todd Whittenton PHONE # 919-427-8465

ADDRESS 843 NEIGHBORS RD DUNN. N.C. 28334

NAME OF MOBILE HOME PARK OR S/D TANNING Ridge lot 7

NAME OF OWNER (IF DIFFERENT) Dale + Carla Sue Lubbens

ADDRESS OF OWNER (IF DIFFERENT) 135 TANNING Ridge Rd. Dunn N.C. 28334

PROPERTY LOCATION: STATE ROAD NAME AND # SR 1802 ^{LANA RD} TANNING Ridge lot 7

PURPOSE OF INSPECTION: Compost

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Marshall
Signature of Environmental Health Specialist

2-16-16
Date