

HTE #: 17-5-40934

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Hugh Surles Builders Phone #: 919-422-7065

Address: 126 Brandon Dr. Lillington, NC 27546

Name of Mobile Home Park or S/D: NA

Name of Owner (if different): Troy Wilkerson

Address of Owner (if different): 1774 Benson Rd. Angier, NC 27501

Property Location (State Road name and #): 1774 Benson Rd. (SR 1500) Angier, NC 27501

Purpose of Inspection: Accessory Garage (60'x40') - Garage with no bathroom/sewage

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM


Signature of Environmental Health Specialist

03/22/17
Date