

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

February 1, 2018

Colt & Rebecca Baxter
340 Marian Lane
Spring Lake, NC 28390

RE: Existing Tank Application HTE# 18-5-43107

Mr. Baxter,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover Outlet end of septic tank (end away from modular home). Shall be uncovered to allow the lid to be opened and inspected. (*\$25.00 fee incurred*)


2. Have system pumped out

3. **Replace sanitary T**

4. Other

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,


Oliver Tolksdorf, R.E.H.S.
Environmental Health Interim Supervisor
Harnett County Department of Public Health
Environmental Health

OT/kh
Copy - Central Permitting