

HTE #: 18-5-43638R

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

**EXISTING SEPTIC SYSTEM INSPECTION**

Name: Susanne Jordan Phone #: 616.406.6553

Address: 129 Oakwater Dr. Cameron, NC 28326

Name of Mobile Home Park or S/D: Bridlewood S/D Lot 9

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): 129 Oakwater Dr. (Hwy NC 24)

Purpose of Inspection: 20'x30' Attached Garage w/ Electrical

**The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.**

**THIS INSPECTION IS VOID IF:**

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

12/11/2018

Date