

## Permit Inspections Harnett County

Permit Number: CDGC18-50044073 Description: 30X50 DETACHED GARAGE

Applied: 5/21/2018 Approved: Site Address: 299 PEANUT LN

Issued: 6/25/2018 Finaled: City, State Zip Code: CAMERON, NC 28326

Status: ISSUED Applicant: TISDALE, JR. JAMES

Parent Permit: Owner: MACAULEY AND MCDONALD INVEST

Parent Project: Contractor: TISDALE HOMES, INC.

Details:

30X50 DETACHED GARAGE COMMENTS: T/S: 05/21/2018 04:24 PM LLUCAS ---- PEANUT LN - CAMERON CYPRESS RD - TO BRIGGS RD - TO LEFT ON PEANUT LN

LIST OF INSPECTIONS										
SEQ ID	SCHEDULED DATE	COMPLETED DATE	ТҮРЕ	INSPECTOR	RESULT	REMARKS				
			ROUGH IN	Scott Guy						
Notes:										
			FINAL**	Scott Guy						
Notes:										
	8/10/2018	8/10/2018	PLUMBING UNDER SLAB	Mike Cook	FAIL W/ PENALTY					
Notes:  1. No plumbing installed in accessory building 2. Fees apply										
	8/14/2018	8/14/2018	UNDERGROUND	Scott Guy	APPROVED					
Notes: Inspector JH changed the inspection assignment from JH to TSG										
	8/17/2018	8/17/2018	SLAB	Scott Guy	APPROVED					
Notes:										
	11/14/2018	11/14/2018	ROUGH IN	Scott Guy	DISAPPROVED					
Notes:  1- verify type heat intended for bathroom area. 2- roof boot missing. 3- access door framing missing for under stair mechanicals. (this area is required to be fire rated at final)Ok to side										
	11/19/2018	11/19/2018	ROUGH IN	Scott Guy	DISAPPROVED					
Notes: Still missing roof boot*do not insulate										
	11/30/2018	11/30/2018	ROUGH IN	Scott Guy	APPROVED					
Notes:										



## Permit Inspections Harnett County

	11/30/2018	11/30/2018	INSULATION	Scott Guy	APPROVED					
Notes:										
	1/2/2019	1/2/2019	ENVIR OPERATIONS PERMIT	Oliver Tolksdorf	APPROVED					
Notes:										
	1/23/2019	1/23/2019	WATER CONNECTION	Scott Guy	APPROVED					
Notes:										
	1/23/2019	1/23/2019	SEWER CONNECTION	Scott Guy	APPROVED					
Notes:										
	2/27/2019	2/27/2019	FINAL**	Scott Guy	DISAPPROVED					
Notes:										
1- secure bathroom sink 2-insulate waterline at door entrance. 3- stone veneer not complete.*top of detached storage only.										