

HTE #: 18-5-44299R

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Pineywoods Construction Phone #: 910.585.2144

Address: 180 Bronwyn Street Southern Pines, NC 28387

Name of Mobile Home Park or S/D: NA

Name of Owner (if different): John & Melissa Bullinger

Address of Owner (if different): 240 Needmore Road Cameron, NC 28326

Property Location (State Road name and #): 240 Needmore Road (SR 1101)

Purpose of Inspection: Accessory Detached Garage/Farm Bldg (36'x40'). No bathroom. No bedrooms. Proposed buildings not within septic field, repair area, or septic setbacks. Future bathrooms shall include permit to pump to existing system or permit for new system.

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

07/10/2018

Date