



# Permit Inspections

## Harnett County

Permit Number: **CFFB05-50011581**

Description: **3 STORY 12 UNITS / BUILDING 9**

Applied: **3/8/2005**

Approved:

Site Address: **62 GALLERY DR UN101**

Issued: **3/8/2005**

Finalized: **10/31/2007**

City, State Zip Code: **SPRING LAKE, NC 28390**

Status: **CERTIFICATE OF OCCUP**

Applicant: **ANDERSON CREEK PARTNERS BLD9**

Parent Permit:

Owner: **ANDERSON CREEK PARTNERS BLD9**

Parent Project:

Contractor: **ELMWOOD BUILDERS LLC**

Details:

**3 STORY 12 UNITS / BUILDING 9 COMMENTS: FAIRWAY POINT AT ANDERSON CREEK BUILDING 9 FROM ENTRANCE TO ANDERSON CREEK CLUB, TAKE ANDERSON CREEK DRIVE, TURN RIGHT ON BARON'S RUN, TURN RIGHT ON WHISPERING PINES, PROJECT WILL BE ON THE LEFT DJOHNSON**

### LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	2/27/2002	2/26/2007	C MECH ROUGH IN	Unassigned	CANCELLED	
Notes:						
	6/19/2006	6/19/2006	BLDG PLAN REVIEW	Unassigned	APPROVED	
Notes:						
	8/1/2006	8/1/2006	R ELEC TEMP SERVICE POLE	Unassigned	APPROVED	
Notes:						
pole at corner of property						
	8/11/2006	8/11/2006	C PLUMB UNDER SLAB	Unassigned	APPROVED	
Notes:						
	8/29/2006	8/29/2006	C BLDG SLAB INSP	Unassigned	APPROVED	
Notes:						
	2/27/2007	2/27/2007	C BLDG ROUGH IN	Unassigned	CANCELLED	
Notes:						
ok for siding and veneer. ce						
	2/27/2007	2/27/2007	C ELEC ROUGH IN	Unassigned	CANCELLED	
Notes:						
ok for siding and veneer. ce						
	2/27/2007	2/27/2007	C MECH ROUGH IN	Unassigned	CANCELLED	
Notes:						
ok for siding and veneer. ce						



# Permit Inspections

## Harnett County

	2/27/2007	2/27/2007	C PLUMB ROUGH IN	Unassigned	CANCELLED	
Notes: ok for siding and veneer. ce						
	2/27/2007	2/26/2007	C BLDG ROUGH IN	Unassigned	CANCELLED	
Notes:						
	4/25/2007	4/24/2007	C BLDG FOOTING	Unassigned	CANCELLED	
Notes: THIS INSPECTION WILL BE FOR A CROSS WALK BRIDGE FOOTINGS. NJT						
	4/26/2007	4/26/2007	C BLDG FOOTING	Unassigned	CANCELLED	
Notes: WILL BE THE FOOTINGS FOR THE PEDESTRIAN BRIDGE. NJT						
	4/30/2007	4/30/2007	C BLDG FOOTING	Unassigned	DISAPPROVED	
Notes: FOR THE BRIDGE. 1)Need engineer letter for unsuitable soil in footings at bottom of hill for bridge. 2)Need engineer to address disturbing soil within 45 degree plain of the existing building footing.						
	5/3/2007	5/1/2007	C BLDG FOOTING	Unassigned	CANCELLED	
Notes: This is a re-inspection of the pedestrian bridge footings. Required letters are on file at inspections dept.						
	5/7/2007	5/7/2007	C BLDG FOOTING	Unassigned	APPROVED	
Notes: Re-inspection for pedestrian bridge footings. Required letter and drawings have been submitted to inspection office						
	5/30/2007	6/7/2007	ADDRESS CONFIRMATION	Unassigned	APPROVED	
Notes: 62 Gallery Dr Bldg 9 Units 101,102,103,104 posted 201,202,203,204 301,302,303,304 Each unit should have it individual #						
	6/15/2007	6/19/2007	C BLDG ROUGH IN	Unassigned	CANCELLED	
Notes:						
	6/15/2007	6/19/2007	C ELEC ROUGH IN	Unassigned	CANCELLED	
Notes:						
	6/15/2007	6/19/2007	C MECH ROUGH IN	Unassigned	CANCELLED	
Notes:						
	6/15/2007	6/19/2007	C PLUMB ROUGH IN	Unassigned	CANCELLED	
Notes:						
	6/20/2007	6/20/2007	C BLDG ROUGH IN	Unassigned	DISAPPROVED	
Notes: support plumbing mid/way of walls fire stop all holes for plumbing ,elect,and mech nail plates repair studs in 302						



# Permit Inspections

## Harnett County

	6/20/2007	6/20/2007	C ELEC ROUGH IN	Unassigned	DISAPPROVED	
Notes: support plumbing mid/way of walls fire stop all holes for plumbing ,elect,and mech nail plates repair studs in 302						
	6/20/2007	6/20/2007	C MECH ROUGH IN	Unassigned	DISAPPROVED	
Notes: support plumbing mid/way of walls fire stop all holes for plumbing ,elect,and mech nail plates repair studs in 302						
	6/20/2007	6/20/2007	C PLUMB ROUGH IN	Unassigned	DISAPPROVED	
Notes: support plumbing mid/way of walls fire stop all holes for plumbing ,elect,and mech nail plates repair studs in 302						
	6/29/2007	6/29/2007	C BLDG ROUGH IN	Unassigned	APPROVED	
Notes:						
	6/29/2007	6/29/2007	C ELEC ROUGH IN	Unassigned	APPROVED	
Notes:						
	6/29/2007	6/29/2007	C INSULATION INSPECTION	Unassigned	APPROVED	
Notes:						
	6/29/2007	6/29/2007	C MECH ROUGH IN	Unassigned	APPROVED	
Notes:						
	6/29/2007	6/29/2007	C PLUMB ROUGH IN	Unassigned	APPROVED	
Notes:						
	10/1/2007	10/1/2007	C ELEC TEMP POWER CERT	Unassigned	CANCELLED	
Notes:						
	10/2/2007	10/1/2007	C ELEC TEMP POWER CERT	Unassigned	CANCELLED	
Notes: cancelled per jeff pope T/S: 10/01/2007 04:47 PM DJOHNSON -----						
	10/22/2007	10/22/2007	PZ ZONING/FINAL INSPECTION	Unassigned	APPROVED	
Notes:						
	10/26/2007	10/30/2007	FM FINAL INSPECTION	Unassigned	APPROVED	
Notes:						
	10/31/2007	10/31/2007	C BLDG FINAL	Unassigned	APPROVED	
Notes:						



# Permit Inspections

## Harnett County

	10/31/2007	10/31/2007	C ELEC FINAL	Unassigned	APPROVED	
Notes:						
	10/31/2007	10/31/2007	C MECH FINAL	Unassigned	APPROVED	
Notes:						
	10/31/2007	10/31/2007	C PLUMB FINAL	Unassigned	APPROVED	
Notes:						

