

# VIOLATION NOTICE

**DO NOT REMOVE!**

## Harnett County Inspection Department

102 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7527 • Fax: (910) 893-2793

Job Name: SIERRA ACADEMY / SIERRA'S SERVICE Date: 4-30-09

Address: 1995 US 421 LILLINGTON, N.C.

Lot No.: \_\_\_\_\_ Permit No.: \_\_\_\_\_

(Check Box for Violation)

- |                                     |                                     |                                  |  |                                     |                                       |                                 |                                      |
|-------------------------------------|-------------------------------------|----------------------------------|--|-------------------------------------|---------------------------------------|---------------------------------|--------------------------------------|
| <input type="checkbox"/> Footing    | <input type="checkbox"/> Foundation | <input type="checkbox"/> Bldg.   | <input type="checkbox"/> Elec.             | <input type="checkbox"/> Plumb.     | <input type="checkbox"/> Mech.        | <input type="checkbox"/> Insul. | <input type="checkbox"/> Floor Fram. |
| <input type="checkbox"/> Floor Slab | <input type="checkbox"/> MFG. Home  | <input type="checkbox"/> Modular | <input type="checkbox"/> Damp/Water Proof. | <input type="checkbox"/> Structural | <input type="checkbox"/> Wall Sheath. | <input type="checkbox"/> Other  |                                      |

Violations Found: ① NEED BUILDING CODE SUMMARY FOR PROPOSED USE - FROM I TO EDUCATIONAL

② NEED HANDICAP PARKING SPACES SIGNS W/ PROPER FINE \$250.00 SIGN + ALL SIGNS TO MEET THE ACCESSIBILITY CODE.

③ NEED COMPLETE DRAWINGS + NOTES FOR THE KITCHEN USE. COMPLY WITH THE CODE

④ DOOR HARDWARE PANIC HARDWARE COMPLY WITH THE CODE

⑤ MOLD LOCATED IN BUILDING.

⑥ TOILET ROOMS SHALL MEET THE HANDICAP-ACCESSIBILITY CODE.

⑦ CENTRAL FIRE ALARM SYSTEMS WITH DRAWINGS UPDATING FOR EDUCATIONAL FACILITY.

8. PLANS SHALL COMPLY WITH THE STATE CODE FOR ANY + ALL PROPOSED USE OF BUILDING.

Code Enforcement Official  
Signature: Lynnwood McDonald

Date: 4-30-09

It is unlawful for any sub contractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation.