

ADDRESS : 1054 NC 24/87
CONTRACTOR : CAIN ELECTRIC COMPANY INC.
OWNER : CAMERON PREMIER PROPERTIES
PARCEL : 01-9594- - -0121- - -
APPL NUMBER: 09-50022911 CP COMMERCIAL MODULAR

SUBDIV: BABCOCK VILLAGE
PHONE : (910) 488-5533
PHONE :

DIRECTIONS : T/S: 09/24/2009 08:33 AM JBROCK ----
NC HWY 27 WEST TO NC HWY 87 NC HWY 87
SOUTH TO SPOUT SPRINGS THIRD LOT ON
LEFT PAST LINDEN OAKS PARKWAY

STRUCTURE: 000 000 1344 SQ. FT. DENTAL OFFICE MOD
FLOOD ZONE : FLOOD ZONE X
PROPOSED USE : DENTAL MOD SEPTIC - EXISTING? : NEW TANK

PERMIT: CPEC 00 CP ELECTRICAL COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E253 01	1/08/10 <i>1-8-10</i>	TI <i>AP</i>	C*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 001868926 T/S: 01/07/2010 03:02 PM NTART

AP
TS

COMMENTS AND NOTES

EXPIRE DATE 2-8-10

T 5417

TEMPORARY POWER CERTIFICATE

JOB NAME CHURCH PREMISES PRS

OWNER _____ ADDRESS _____ PHONE _____

LOCATION 10541 NC 24/27

CMA The power company shall not be required to terminate electric service supplied to the premises described above on or after the expiration date specified in this certificate, unless and until it is notified in writing by the Harnett County Electrical Inspector to do so.

I the undersigned understand that this certificate is for Temporary Power only and that a final inspection is required before permanent power will be approved. I shall also comply with any special requirement requested by the Harnett County Inspection Department.

Date 2-8-10

Owner or Authorized Signature

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code certifying at the time of issuance this structure was in temporary compliance with the various ordinances of the County of Harnett regulating building construction or use.

Date 2-8-10

[Signature]
Building Official

ADDRESS . . : 1054 NC 24/87 SUBDIV: BABCOCK VILLAGE
CONTRACTOR : PHONE :
OWNER . . . : CAMERON PREMIER PROPERTIES PHONE :
PARCEL . . . : 01-9594- - -0121- - -
APPL NUMBER: 09-50022911 CP COMMERCIAL MODULAR
DIRECTIONS : T/S: 09/24/2009 08:33 AM JBROCK -----
NC HWY 27 WEST TO NC HWY 87 NC HWY 87
SOUTH TO SPOUT SPRINGS THIRD LOT ON
LEFT PAST LINDEN OAKS PARKWAY

STRUCTURE: 000 000 1344 SQ. FT. DENTAL OFFICE MOD
FLOOD ZONE : FLOOD ZONE X
PROPOSED USE : DENTAL MOD SEPTIC - EXISTING? : NEW TANK

PERMIT: CPMH 00 CP MODULAR

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/22/09 <i>12/22/09</i>	TI <i>As Dd</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001864339

----- COMMENTS AND NOTES -----

ADDRESS : 1054 NC 24/87
CONTRACTOR : CAIN ELECTRIC COMPANY INC.
OWNER : CAMERON PREMIER PROPERTIES
PARCEL : 01-9594- - -0121- - -
APPL NUMBER: 09-50022911 CP COMMERCIAL MODULAR

SUBDIV: BABCOCK VILLAGE
PHONE : (910) 488-5533
PHONE :

DIRECTIONS : T/S: 09/24/2009 08:33 AM JBROCK ----
NC HWY 27 WEST TO NC HWY 87 NC HWY 87
SOUTH TO SPOUT SPRINGS THIRD LOT ON
LEFT PAST LINDEN OAKS PARKWAY

STRUCTURE: 000 000 1344 SQ. FT. DENTAL OFFICE MOD

FLOOD ZONE : FLOOD ZONE X

PROPOSED USE : DENTAL MOD

SEPTIC - EXISTING? : NEW TANK

PERMIT: CPMH 00 CP MODULAR

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/22/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001864339
	12/22/09	AP	
A814 01	1/28/10	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001877018 T/S: 01/27/2010 12:31 PM NTART
B103 01	1/28/10	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001877349
	<u>1-28-10</u>	<u>AP-MR</u>	T/S: 01/27/2010 02:47 PM NTART
B117 01	1/28/10	TI	R*MODULAR ROUGH-IN TIME: 17:00 VRU #: 001877364
	<u>1-28-10</u>	<u>DA-MR</u>	T/S: 01/27/2010 02:47 PM NTART
B119 01	1/28/10	TI	R*MOD MARRIAGE WALL TIME: 17:00 VRU #: 001877356
	<u>1-28-10</u>	<u>AP-MR</u>	T/S: 01/27/2010 02:47 PM NTART

PERMIT: CPDC 00 CP PLUMBING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P353 01	1/28/10	TI	C*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 001877000
	<u>1-28-10</u>	<u>AP-MR</u>	T/S: 01/27/2010 12:30 PM NTART
P355 01	1/28/10	TI	C*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 001876994
	<u>1-28-10</u>	<u>AP-MR</u>	T/S: 01/27/2010 12:30 PM NTART

COMMENTS AND NOTES

Kelly Cain
308-9076

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 01-28-10

PERMIT # 09-50022911

ADDRESS: 1054 nc 24/87

VIOLATIONS:

1. Wiring to patient care areas must comply with NEC 517.13 A as regards wiring conductors and redundant grounding raceways.
2. Plumbing drain lines must be plugged and filled for drain test with a 10' head
3. Some grounds are only twisted together and not connected with approved connectors
4. Provide a 30" wide and 36" clearance in front of all panels
5. Water heater is to sit on a concrete pad and the relief line is to extend outside of the foundation
6. Reveal the two ground rods
7. Accessible parking signage must be installed per code, min. 75" to bottom

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS . . : 1044 NC 24/87
CONTRACTOR : CAIN ELECTRIC COMPANY INC.
OWNER . . . : CAMERON PREMIER PROPERTIES
PARCEL . . . : 01-9594- - -0121- - -
APPL NUMBER: 09-50022911 CP COMMERCIAL MODULAR

SUBDIV: BABCOCK VILLAGE
PHONE : (910) 488-5533
PHONE :

DIRECTIONS : T/S: 09/24/2009 08:33 AM JBROCK ----
NC HWY 27 WEST TO NC HWY 87 NC HWY 87
SOUTH TO SPOUT SPRINGS THIRD LOT ON
LEFT PAST LINDEN OAKS PARKWAY

STRUCTURE: 000 000 1344 SQ. FT. DENTAL OFFICE MOD

FLOOD ZONE : FLOOD ZONE X

PROPOSED USE : DENTAL MOD

SEPTIC - EXISTING? : NEW TANK

PERMIT: CPLU 00 CP LAND USE PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
Z818 01	2/04/10 <u>2/4/10</u>	TI <u>RB/AC</u>	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 001879816 T/S: 02/04/2010 10:48 AM VBROWN

COMMENTS AND NOTES

Verify parking spaces have parking stops.

ADDRESS : 1044 NC 24/87
 CONTRACTOR : CAIN ELECTRIC COMPANY INC.
 OWNER : CAMERON PREMIER PROPERTIES
 PARCEL : 01-9594- - -0121- - -
 APPL NUMBER: 09-50022911 CP COMMERCIAL MODULAR

SUBDIV: BABCOCK VILLAGE
 PHONE : (910) 488-5533
 PHONE :

DIRECTIONS : T/S: 09/24/2009 08:33 AM JBROCK ----
 NC HWY 27 WEST TO NC HWY 87 NC HWY 87
 SOUTH TO SPOUT SPRINGS THIRD LOT ON
 LEFT PAST LINDEN OAKS PARKWAY

STRUCTURE: 000 000 1344 SQ. FT. DENTAL OFFICE MOD
 FLOOD ZONE : FLOOD ZONE X
 PROPOSED USE : DENTAL MOD SEPTIC - EXISTING? : NEW TANK

PERMIT: CPMH 00 CP MODULAR

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/22/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001864339
	12/22/09	AP	
A814 01	1/28/10	FB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001877018
	1/28/10	AP	T/S: 01/27/2010 12:31 PM NTART ----- T/S: 01/28/2010 01:02 PM FBURGESS ----- 1044 NC 24-87 CAMERON, NC 28326 LOT 106
B103 01	1/28/10	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001877349
	1/28/10	AP	T/S: 01/27/2010 02:47 PM NTART ----- T/S: 01/28/2010 01:46 PM MREARIC -----
B117 01	1/28/10	MR	R*MODULAR ROUGH-IN TIME: 17:00 VRU #: 001877364
	1/28/10	DA	T/S: 01/27/2010 02:47 PM NTART ----- T/S: 01/28/2010 01:46 PM MREARIC ----- drain test needed electrical circuits in patient care areas do not appear to meet code NEC 517.13 T/S: 02/04/2010 03:24 PM NTART -----
B119 01	1/28/10	MR	R*MOD MARRIAGE WALL TIME: 17:00 VRU #: 001877356
	1/28/10	AP	T/S: 01/27/2010 02:47 PM NTART ----- T/S: 01/28/2010 01:48 PM MREARIC -----
B117 02	2/05/10	TI	R*MODULAR ROUGH-IN TIME: 17:00 VRU #: 001880210
	<u>2-5-10</u>	<u>AP-MR</u>	T/S: 02/05/2010 10:04 AM NTART ----- T/S: 02/05/2010 12:07 PM NTART -----

PERMIT: CPPC 00 CP PLUMBING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P353 01	1/28/10	MR	C*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 001877000
	1/28/10	DA	T/S: 01/27/2010 12:30 PM NTART ----- T/S: 01/28/2010 01:49 PM MREARIC ----- drain test needed T/S: 02/05/2010 12:08 PM NTART -----
P355 01	1/28/10	MR	C*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 001876994
	1/28/10	AP	T/S: 01/27/2010 12:30 PM NTART ----- T/S: 01/28/2010 01:52 PM MREARIC -----
P353 03	2/05/10	TI	C*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 001880335
	<u>2-5-10</u>	<u>AP-MR</u>	T/S: 02/05/2010 12:09 PM NTART -----

ADDRESS : 1044 NC 24/87
CONTRACTOR : CAIN ELECTRIC COMPANY INC.
OWNER : CAMERON PREMIER PROPERTIES
PARCEL : 01-9594- - -0121- - -
APPL NUMBER: 09-50022911 CP COMMERCIAL MODULAR
DIRECTIONS : T/S: 09/24/2009 08:33 AM JBROCK ----
NC HWY 27 WEST TO NC HWY 87 NC HWY 87
SOUTH TO SPOUT SPRINGS THIRD LOT ON
LEFT PAST LINDEN OAKS PARKWAY

SUBDIV: BABCOCK VILLAGE
PHONE : (910) 488-5533
PHONE :

STRUCTURE: 000 000 1344 SQ. FT. DENTAL OFFICE MOD
FLOOD ZONE : FLOOD ZONE X
PROPOSED USE : DENTAL MOD SEPTIC - EXISTING? : NEW TANK

PERMIT: CBCO 00 CP BUILDING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
F854 01	1/27/10 1/27/10	TM AP	FM*FINAL INSPECTION TIME: 17:00 VRU #: 001877273 T/S: 01/27/2010 02:08 PM NTART T/S: 01/27/2010 02:09 PM NTART APPROVED FINAL FIRE MARSHALL PER TJ MCLAMB.....
H824 01	2/09/10 2/09/10	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001880897 T/S: 02/09/2010 08:40 AM S STEWART T/S: 02/09/2010 08:41 AM S STEWART
C179 01	2/10/10 <u>2-10-10</u>	TI <u>AP-IVR</u>	C*BLDG FINAL TIME: 17:00 VRU #: 001880954 T/S: 02/09/2010 09:16 AM NTART

PERMIT: CPEC 00 CP ELECTRICAL COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E253 01	1/08/10 1/08/10	FS AP	C*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 001868926 T/S: 01/07/2010 03:02 PM NTART T/S: 01/08/2010 12:09 PM FSPIVEY
E265 01	2/10/10 <u>2-10-10</u>	TI <u>AP-MR</u>	C*ELEC FINAL TIME: 17:00 VRU #: 001880962 T/S: 02/09/2010 09:16 AM NTART

PERMIT: CPMH 00 CP MODULAR

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/22/09 12/22/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001864339
A814 01	1/28/10 1/28/10	FB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001877018 T/S: 01/27/2010 12:31 PM NTART T/S: 01/28/2010 01:02 PM FBURGESS
B103 01	1/28/10 1/28/10	MR AP	✓ 1044 NC 24-87 CAMERON, NC 28326 LOT 106 R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001877349 T/S: 01/27/2010 02:47 PM NTART T/S: 01/28/2010 01:46 PM MREARIC
B117 01	1/28/10 1/28/10	MR DA	R*MODULAR ROUGH-IN TIME: 17:00 VRU #: 001877364 T/S: 01/27/2010 02:47 PM NTART T/S: 01/28/2010 01:46 PM MREARIC drain test needed electrical circuits in patient care areas do not appear to

ADDRESS : 1044 NC 24/87
 CONTRACTOR : CAIN ELECTRIC COMPANY INC.
 OWNER : CAMERON PREMIER PROPERTIES
 PARCEL : 01-9594- - -0121- - -
 APPL NUMBER: 09-50022911 CP COMMERCIAL MODULAR

SUBDIV: BABCOCK VILLAGE
 PHONE : (910) 488-5533
 PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
			meet code NEC 517.13
B119 01	1/28/10	MR	T/S: 02/04/2010 03:24 PM NTART ----- R*MOD MARRIAGE WALL TIME: 17:00 VRU #: 001877356
	1/28/10	AP	T/S: 01/27/2010 02:47 PM NTART -----
B117 02	2/05/10	MR	T/S: 01/28/2010 01:48 PM MREARIC ----- R*MODULAR ROUGH-IN TIME: 17:00 VRU #: 001880210
	2/05/10	AP	T/S: 02/05/2010 10:04 AM NTART ----- T/S: 02/05/2010 12:07 PM NTART ----- T/S: 02/05/2010 12:10 PM NTART -----
R131 01	2/10/10	TI	ONE TRADE FINAL TIME: 17:00 VRU #: 001880939
	<u>2-10-10</u>	<u>AP-MR</u>	T/S: 02/09/2010 09:15 AM NTART -----

PERMIT: CPPC 00 CP PLUMBING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P353 01	1/28/10	MR	C*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 001877000
	1/28/10	DA	T/S: 01/27/2010 12:30 PM NTART ----- T/S: 01/28/2010 01:49 PM MREARIC ----- drain test needed
			T/S: 02/05/2010 12:08 PM NTART -----
P355 01	1/28/10	MR	C*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 001876994
	1/28/10	AP	T/S: 01/27/2010 12:30 PM NTART ----- T/S: 01/28/2010 01:52 PM MREARIC -----
P353 03	2/05/10	MR	C*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 001880335
	2/05/10	AP	T/S: 02/05/2010 12:09 PM NTART ----- T/S: 02/05/2010 12:10 PM NTART -----
P353 02	2/05/10	TI	C*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 001880228
	2/05/10	CA	T/S: 02/05/2010 10:04 AM NTART ----- T/S: 02/05/2010 12:06 PM NTART -----
P361 01	2/10/10	TI	C*PLUMB FINAL TIME: 17:00 VRU #: 001880970
	<u>2-10-10</u>	<u>AP-MR</u>	T/S: 02/09/2010 09:16 AM NTART -----

COMMENTS AND NOTES

PREPARED 1/07/10, 15:03:17
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

SCANNED
6/29/10
DATE

PAGE 1
DATE 1/08/10

ADDRESS : 1054 NC 24/87
CONTRACTOR : CAIN ELECTRIC COMPANY INC.
OWNER : CAMERON PREMIER PROPERTIES
PARCEL : 01-9594- - -0121- - -
APPL NUMBER: 09-50022911 CP COMMERCIAL MODULAR

SUBDIV: BABCOCK VILLAGE
PHONE : (910) 488-5533
PHONE :

DIRECTIONS : T/S: 09/24/2009 08:33 AM JBROCK ----
NC HWY 27 WEST TO NC HWY 87 NC HWY 87
SOUTH TO SPOUT SPRINGS THIRD LOT ON
LEFT PAST LINDEN OAKS PARKWAY

STRUCTURE: 000 000 1344 SQ. FT. DENTAL OFFICE MOD
FLOOD ZONE : FLOOD ZONE X
PROPOSED USE : DENTAL MOD SEPTIC - EXISTING? : NEW TANK

PERMIT: CPEC 00 CP ELECTRICAL COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E253 01	1/08/10 <i>1-8-10</i>	TR <i>AP</i>	C*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 001868926 T/S: 01/07/2010 03:02 PM NTART

COMMENTS AND NOTES

#5

EXPIRE DATE 2-8-10

T 5417

TEMPORARY POWER CERTIFICATE

JOB NAME CARROLL PREMIER FC

OWNER _____ ADDRESS _____ PHONE _____

LOCATION 1054 NC 24127

CMA The power company shall not be required to terminate electric service supplied to the premises described above on or after the expiration date specified in this certificate, unless and until it is notified in writing by the Harnett County Electrical Inspector to do so.

I the undersigned understand that this certificate is for Temporary Power only and that a final inspection is required before permanent power will be approved. I shall also comply with any special requirement requested by the Harnett County Inspection Department.

Date 2-8-10

Owner or Authorized Signature

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code certifying at the time of issuance this structure was in temporary compliance with the various ordinances of the County of Harnett regulating building construction or use.

Date 2-8-10

[Signature]
Building Official