

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: BOBBY MURRAY (VICTORY BAPTIST CH) PROPERTY LOCATION: LASIER RD SUBDIVISION LOT # NEW REPAIR EXPANSION Type of Structure: CHURCH w/ KITCHEN Proposed Wastewater System Type: 25% REDUCTION SYSTEM Projected Daily Flow: 500 GPD Number of bedrooms: Number of Occupants: 100 max Basement Pump Required: Type of Water Supply: Permit conditions: Permit valid for: Five years No expiration

Authorized State Agent: REGNS Date: 10/30/17 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: BOBBY MURRAY PROPERTY LOCATION: LASIER RD SUBDIVISION LOT # Facility Type: CHURCH w/ KITCHEN New Expansion Repair Basement? Type of Wastewater System: 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 500 GPD (See note below, if applicable) 25% RED. SYS (Repair)

Installation Requirements/Conditions Number of trenches: 4 Septic Tank Size: 1000 gallons Exact length of each trench: 80 feet Trench Spacing: 7 feet on center Pump Tank Size: gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18 inches Soil Cover: 6 inches (Maximum soil cover shall not exceed 36" above the trench bottom) Pump Requirements: ft. TDH vs. GPM Aggregate Depth: inches below pipe inches above pipe inches total Conditions:

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: Date:

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: REGNS Date: 10/30/17 Construction Authorization Expiration Date: 10/31/22


HTE# 17-5-42037R

Permit # 29738

Harnett County Department of Public Health Site Sketch

ISSUED TO: Bobby Murray PROPERTY LOCATOR: LASTER RD
SUBDIVISION _____ LOT # _____

Authorized State Agent: ~~RENS (OLIVER TOLKSCOFF)~~ Date: 10/30/07



SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: *100 S. G. W. R. W.* Design Flow (.1949): *500 gpd* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1		0-20	GS						
		20-36	SBK SCL	FR S/SX	10-12 7/2 @ 27"				PS .4
2		0-32	GS						
		32-40	SBK SCL		10-11 1/2 @ 10"				PS .4
3		0-15	GS	VFA NS/VP					
		15-30	SBK C	FR S/SX	CR @ 26"				PS .4
4		0-15"	GS	VFA NS/VP					
		15-30"	SBK C	FR S/SX	CR @ 25"				PS .4
5		0-36	GS	VF NS/VP					
		36-40	SBK SCL	FR S/SX					PS .4
		40"	FR S/SX						
6		0-26	GS						
		26-40	SBK SCL		CR @ 38"				PS .4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>DS</i> Others Present: -
Available Space (.1945)	<i>✓</i>	<i>✓</i>	
System Type(s)	<i>25" @ 25"</i>		
Site LTAR	<i>.5</i>	<i>.5</i>	