


SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940										
SLOPE (%)	.1940										
HORIZON 1 DEPTH		0-6	0-34	0-40	0-38	0-36					
Texture Group	.1941(A)(1)	cl/sl	sl	cl/sl	cl/sl	sl					
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 2 DEPTH		6-26	34-42								
Texture Group	.1941(A)(1)	sl	sl								
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 3 DEPTH		26-42									
Texture Group	.1941(A)(1)	cl/sl									
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942	42"	—	—	—	—					
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/1956										
CLASSIFICATION	.1948	ps	ps	s	s	s					
LONG TERM ACCEPTANCE RATE	.1955	.6	.8	.8	.8	.8					



#2x75' lines
 at 24" deep
 # laid out
 # filter
 # maintain s/b back