

OPERATIONS PERMIT

Name: (owner) Jeremy Haire New Installation Septic Tank
 Property Location: SR# 1210 Repairs Nitrification Line
 Subdivision Wesco Land Lot # 1
 TAX ID# _____ Quadrant # _____
 Contractor: Lonnice Johnson Registration # _____
 Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50 ft.


Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field No. of ditches 1 exact length of each ditch 300 ft. width of ditches 3 ft. depth of ditches 12 in.
 French Drain: _____ Linear feet

Date: 12-13-2000

PERMIT NO. _____

Inspected by: Joe L. Ar...
Environmental Health Specialist



SR
1210