

00-011616

HARNETT COUNTY HEALTH DEPARTMENT

No 18141

IMPROVEMENT PERMIT

00-5000521

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Tom Luoter

☒ New Installation

☒ Septic Tank

Property Location: SR# 1232

☐ Repairs

☒ Nitrification Line

Subdivision

Lot #

Tax ID # 13-0509-0044-01 Split

Quadrant # 0600-65-1158 Split

Number of Bedrooms Proposed: Three

Lot Size:

Basement with Plumbing:

☐

Garage:

☐

Water Supply: ☐ Well

☒ Public

☐ Community

Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☒ Conventional

☐ Other

Size of tank:

Septic Tank: 1000 gallons

Pump Tank: _____ gallons

Subsurface
Drainage Field

No. of
ditches

2

exact length
of each ditch

150 ft.

width of
ditches

3 ft.

depth of
ditches

18 max in.

French Drain Required: _____ Linear feet

Date:


30 October 2000

Signed:

Vernon R. Dodge, R.S.
Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

*system laid out
*maintain setbacks
*10' off all property lines



HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT

DD-50000521

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 18141. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent _____

Name: Tom Lasater Telephone # 499-6935

Address: 337 Buie Road Broadway, NC

Property Location: SR # 1232 Road Name Cameron

New Installation ☒ Repair ☐ Septic Tank ☒ Nitrification Lines ☒

Subdivision _____ Lot # _____

Number of Bedrooms Proposed: Three Lot size: _____

Basement _____ With Plumbing _____ Without Plumbing _____

Water Supply: Well _____ Public ☒ Minimum Well Setback: 50 ft.

Type of System: Conventional ☒ Other _____

Tank Volume: Septic Tank 1000 gallons Pump Chamber _____ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 2 Length of lines 150 feet

Width of ditches 3 ft. Depth of ditches 18 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Verneth. Rode, JR Date: 30 Oct 2000