


SITE/S... EVALUATION FOR ON-SIT... WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L	L	L						
SLOPE (%)	.1940	2	2	2	2						
HORIZON 1 DEPTH		0-18	0-20	0-20	0-18						
Texture Group	.1941(A)(1)	SL	SL	SL	SL						
Consistence	.1941	FL	FL	FL	FL						
Structure	.1941(A)(2)	GL	GL	GL	GL						
Mineralogy	.1941(A)(3)	NSNP	NSNP	NSNP	NSNP						
HORIZON 2 DEPTH		18-24	20-24	20-24	18-24						
Texture Group	.1941(A)(1)	SCL	SCL	SCL	SCL						
Consistence	.1941	FL	FL	FL	FL						
Structure	.1941(A)(2)	GL	GL	GL	GL						
Mineralogy	.1941(A)(3)	SSP	SSP	SSP	SSP						
HORIZON 3 DEPTH		24-36	24-34	24-36	24-26						
Texture Group	.1941(A)(1)	sc d	sc d	sc d	sc d						
Consistence	.1941	FL	FL	FL	FL						
Structure	.1941(A)(2)	PSL	PSL	PSL	PSL						
Mineralogy	.1941(A)(3)	SSP	SSP	SSP	SSP						
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942	36 ^{cut}	36 ^{cut}	36 ^{cut}	36 ^{cut}						
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/1956										
CLASSIFICATION	.1948	PS	PS	PS	PS						
LONG TERM ACCEPTANCE RATE	.1955	.35	.3	.35	.3						



Silas Moore RD SR 1557

Required Property Line Setbacks

	Minimum	Actual
Front	<u>35</u>	<u>86</u>
Side	<u>10</u>	<u>19</u>
Corner	<u>20</u>	<u>86</u>
Rear	<u>25</u>	<u>86</u>
Nearest Building	<u>10</u>	<u>86</u>

USE PLAN APPROVAL
 DISTRICT RA-ZCM USE DWUH

#BEDROOMS 4

27 Feb 01 [Signature]
 Zoning Administrator