

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L	L	L	L	L	L	L		
SLOPE (%)	.1940	5%	5%	5%	5%	5%	5%	5%	5%		
HORIZON 1 DEPTH		0-12"	0-22"	0-18"	0-30"	0-24"	0-24"	0-36"	0-36"		
Texture Group	.1941(A)(1)	LS	LS	LS	LS	LS	LS	LS	LS		
Consistence	.1941	VFR	VFR	VFR	VFR	VFR	VFR	VFR	VFR		
Structure	.1941(A)(2)	G	G	G	G	G	G	G	G		
Mineralogy	.1941(A)(3)	NS/NP	NS/NP	NS/NP	NS/NP	NS/NP	NS/NP	NS/NP	NS/NP		
HORIZON 2 DEPTH		14-30"	28-48"			24-48"	24-48"	36"	36"		
Texture Group	.1941(A)(1)	SCL	SCL			SC	SZ	SCL	SCL		
Consistence	.1941	FR	FR			FR	VFR	VFR	VFR		
Structure	.1941(A)(2)	SBK	SBK			SBK	C	SBK	SBK		
Mineralogy	.1941(A)(3)	SS/SP	SS/SP			SS/SP	NS/NP	NS/NP	NS/NP		
HORIZON 3 DEPTH		30"									
Texture Group	.1941(A)(1)	SC									
Consistence	.1941	FR									
Structure	.1941(A)(2)	SBK									
Mineralogy	.1941(A)(3)	SS/SP									
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942	33"	30"	27"		36"	31"				
RESTRICTIVE HORIZON	.1944				30"						
SAPROLITE	.1943/1958										
CLASSIFICATION	.1948	US/PS	US/PS	US/PS	US/PS						
LONG TERM ACCEPTANCE RATE	.1955	.4	.4	.8	.8	.4	.8				

PHYSICAL WES @ G, # 3, # 1


4 100' LINES
18" DEEP
9' O.C.

SHALLOW CONVENTIONAL
LINES RUN ON CONTOUR

LTPAL
35'

1x 480 of line

4x120



LAP REPAIR (C)