

# SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME \_\_\_\_\_

DATE \_\_\_\_\_

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L	L	L	L					
SLOPE (%)	.1940	0-2%	0-2%	0-2%	0-2%	0-2%					
HORIZON 1 DEPTH		0-48	0-48	0-48	0-48	0-48					
Texture Group	.1941(A)(1)	LS	LS	LS	LS	LS					
Consistence	.1941	VFR	VFR	VFR	VFR	VFR					
Structure	.1941(A)(2)	G	G	G	G	G					
Mineralogy	.1941(A)(3)	NS/NP	NS/NP	NS/NP	NS/NP	NS/NP					
<b>HORIZON 2 DEPTH</b>											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
<b>HORIZON 3 DEPTH</b>											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
<b>HORIZON 4 DEPTH</b>											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942										
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/1956										
CLASSIFICATION	.1948	S	S	S	S	S					
LONG TERM ACCEPTANCE RATE	.1955	1.0	1.0	1.0	1.0	1.0					

CON. SYS.  
 2 20' LINES  
 3' WIDE  
 24"-30" DEEP  
 9' ON CENTER

