

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L	L							
SLOPE (%)	.1940	Z	Z	Z							
HORIZON 1 DEPTH		0-18	0-18	0-18							
Texture Group	.1941(A)(1)	SL	SL	SL							
Consistence	.1941	FR	FR	FR							
Structure	.1941(A)(2)	GR	GR	GR							
Mineralogy	.1941(A)(3)	NSNP	NSNP	NSNP							
HORIZON 2 DEPTH		18-24	18-24	18-24							
Texture Group	.1941(A)(1)	SCL	SCL	SCL							
Consistence	.1941	FR	FR	FR							
Structure	.1941(A)(2)	GR	GR	GR							
Mineralogy	.1941(A)(3)	SSSP	SSSP	SSSP							
HORIZON 3 DEPTH		24-42	24-42	24-42							
Texture Group	.1941(A)(1)	SC CL	SC CL	SC CL							
Consistence	.1941	FR	FR	FR							
Structure	.1941(A)(2)	ABK	ABK	ABK							
Mineralogy	.1941(A)(3)	SSSP	SSSP	SSSP							
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942	32	34	36							
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/1956										
CLASSIFICATION	.1948										
LONG TERM ACCEPTANCE RATE	.1955	.4	.4	.4							

Date

SITE PLAN APPROVAL

DISTRICT RADOM USE DwM#

#BEDROOMS 3

Date 5-2-01 Theresa Forner
Zoning Administrator

DENA YOUNG
PEREGOY

Deed Book 813,
Page 163

Required Property Line Setbacks

	Minimum	Actual
Front	<u>35</u>	<u>60</u>
Side	<u>10</u>	<u>20</u>
Corner	<u>20</u>	<u>10</u>
Rear	<u>25</u>	<u>20</u>
Nearest Building	<u>10</u>	<u>11</u>

MILTON RAY WILLIFORD

LEE VON YOUNG
Book 813, Page 161

