

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940										
SLOPE (%)	.1940	2%									
HORIZON 1 DEPTH		0-12	0-12	0-12	0-12	0-18"	0-18"	0-18"	0-18"		
Texture Group	.1941(A)(1)	SL	SL	SL	SL	SL	SL	SL	SL		
Consistence	.1941	VFR				VFR	VFR	NFR	VFR		
Structure	.1941(A)(2)	G				G	G	G	C		
Mineralogy	.1941(A)(3)	NS/NP				NS/NP	NS/NP	NS/NP	NS/NP		
HORIZON 2 DEPTH		12-30	12"	12"	12"	18"-36"	18-40"	18"-36"	18-38"		
Texture Group	.1941(A)(1)	CL	CL	CL	CL	CL	CL	C/CL	CL		
Consistence	.1941	FR				FR	FR	FR	FR		
Structure	.1941(A)(2)	SBK				SBK	SBK	SBK	SBK		
Mineralogy	.1941(A)(3)	SS/SP				SS/SP	SS/SP	SS/SP	SS/SP		
HORIZON 3 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942	20"	20"	20"	24"	30"	32"	28"	30"		
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948	US	US	US	US	PS	PS	US	PS		
LONG TERM ACCEPTANCE RATE	.1955	.5	.5	.5	.5	.5	.5	.4	.5		

