

# SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME \_\_\_\_\_

DATE \_\_\_\_\_

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-24	0-18	0-18											
Texture Group	.1941(A)(1)	LS	LS	LS											
Consistence	.1941		1												
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 2 DEPTH		24-36	17-30	18-30											
Texture Group	.1941(A)(1)	SC	SC	SC											
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 3 DEPTH			36-48	30-36											
Texture Group	.1941(A)(1)		SC	SC											
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 4 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
SOIL WETNESS	.1942														
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/1956														
CLASSIFICATION	.1948														
LONG TERM ACCEPTANCE RATE	.1955														

One to soil  
I have a recall  
to prep





Leonard Kray Mims & Billie Lee Moffitt  
 D.B. 1078, Pg. 622; P.C. F, Slide 702-A  
 PIN 0555-17-1569

THE LOT(S) ON THIS PLAN HAVE BEEN EVALUATED BY A PRIVATE CONSULTANT. BASED ON THIS REVIEW, IT APPEARS THAT LOT(S) ON THIS PLAT MEET APPROPRIATE REGULATIONS. NOTE THAT FINAL APPROVAL FOR EACH LOT REQUIRES ISSUANCE OF THE APPROPRIATE HARNETT COUNTY HEALTH DEPARTMENT PERMITS FOR SPECIFIC USE AND SITING IN ACCORDANCE WITH REGULATIONS IN FORCE AT THE TIME OF PERMITTING. THIS CERTIFICATION DOES NOT REPRESENT APPROVAL OR A PERMIT FOR ANY SITE WORK.

**CERTIFICATION OF OWNERS**  
 I (WE) hereby certify that I am (we) the owner(s) of the property shown and described in this subdivision with my(our) tree setback lines, and dedicate all easements and easements to public use shown hereon is within the sub Harnett County except:

8/10/2000  
 DATE  
 P. M. Lewis, D. S.  
 ENVIRONMENTAL HEALTH

8-9-2000  
 Date

**NOTE:**  
 No N.C.G.S. Monun or State Agency Surv to exist within 2000  
 In lieu of such cor properties, and/or o were used as referer  
 Previously recorded establish bearing cor

**Required Property Setbacks**

Actual	Required
50	35
10	10
20	20
500	500

Front  
Side  
Corner

18 Subd  
Revised  
CLB

229.63' Rear Building

200.00' Zoning Administrator

Swamp (Creek)

237.09' (351.17' total)

5-5

NA


USE/RE

DISTRICT

#BEDROOMS

5-5


11



\*350  
 5 Bedrooms

Esther I  
 D.B. 10  
 P. C. F,  
 PIN 055

*[Signature]*  
 Owner of



Call halowms  
for layout

05/26/00

SEPTI STEM LAYOUT DESIGN: FIELD EET

Project/Site: Lot 6, Walker Estates

Lot #: 6

# Bedrooms 3

Investigator LF

House Footprint \_\_\_\_\_ Setbacks \_\_\_\_\_  
 Date \_\_\_\_\_

Slope: \_\_\_\_\_ Foundation Drain: YES NO

Line No.	Line color	Field Length	System Length	Field Elevation			Relative Elevation
				Setup #1	Setup #2	Setup #3	
1	?	40					
2	Y	43		2.87		104.77	
3	B	59		4.35		103.29	
4	R	63		5.25		102.39	
5	Y	65		6.44		101.20	
6	B	67		7.58		100.06	
7	R	26		8.83		98.81	
8	B	79		13.08	3.18	94.56	
9	Y	95			5.48	92.26	
10	R	105			7.39	90.35	
11	B	101			9.34	88.40	
12							
13							
14							
EIP Benchmark				7.64		100.0	

PROPOSED SYSTEM:

Initial System

X

@

LTAR

Repair System

X

@

LTAR

Scale

Lines 1-7 in front of house are on 10' centers.  
 Lines 8-11 are in back of house and are on 18' centers.