HA[illegible]TT COUNTY HEALTH DEPART[illegible]NT
[illegible]IRONMENTAL HEALTH SECTI[illegible]

№ 10896

# OPERATIONS PERMIT

Name: (owner) Kenneth Ray Lee

☑ New Installation ☑ Septic Tank

Property Location: SR# 1551 Bailey Cromwell Deanne Ln

☐ Repairs ☑ Nitrification Line

Subdivision Quail Hollow Phase III Lot # 2

TAX ID#_____ Quadrant #_____

Contractor: Mike Ray Registration #_____

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☑ Well ☑ Public ☐ Community

Distance From Well: 50' ft.

**Following are the specifications for the sewage disposal system on above captioned property.**

Type of system: ☑ Conventional ☐ Other_____

Size of tank: Septic Tank: 1000 gallons Pump Tank:_____ gallons

Subsurface Drainage Field: No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 16-18 in.

French Drain: — Linear feet

Date: 6-20-01

**PERMIT NO.** 18434

Inspected by: James C Manhart
Environmental Health Specialist