

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940										
SLOPE (%)	.1940										
HORIZON 1 DEPTH		0-12	0-12	0-36	0-30	0-14	0-12	0-30	0-16		
Texture Group	.1941(A)(1)	SL	SL	SL	SL	SL	SL	SL	SL		
Consistence	.1941	VFR	VFR	VFR	VFR	VFR	VFR	VFR	VFR		
Structure	.1941(A)(2)	G	G		G	G	G	G	G		
Mineralogy	.1941(A)(3)	NS/NP	NS/NP		NS/NP	NS/NP	NS/NP	NS/NP	NS/NP		
HORIZON 2 DEPTH		12"	12"		30-36	14-36	10"	30-36"	16-38		
Texture Group	.1941(A)(1)	Pm	Pm		SCL	SCL	PM	SCL	SCL		
Consistence	.1941				FR	FR		FR	FR		
Structure	.1941(A)(2)				SBK	SBK		SBK	SBK		
Mineralogy	.1941(A)(3)				SS/SP	SS/SP		SS/SP	SS/SP		
HORIZON 3 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942			36"	34"	34"					
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1958					Pm 34"			Pm 38"		
CLASSIFICATION	.1948	US/BS	US/BS	PS	PS	PS	US/BS	PS	PS		
LONG TERM ACCEPTANCE RATE	.1955			.8	.6	.6		.6	.6		

1 200' LINE (NOT INCLUDING STEP DOWNS)
 18"-22"
 USE STEP DOWNS AS NECESSARY