ARNETT COUNTY HEALTH DE TMENT
ENVIRONMENTAL HEALTH S TION

№ 14623

OPERATIONS PERMIT

01-5-2691

Name: (owner) Robert Edwards ☒ New Installation ☒ Septic Tank

Property Location: SR# 1203 ☐ Repairs ☒ Nitrification Line

Subdivision Lofton Ford Lot # 2

TAX ID# _____ Quadrant # _____

Contractor: W. Sharpe Registration # _____

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☒ Conventional ☐ Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field: No. of ditches 1 exact length of each ditch 240 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain: _____ Linear feet

Date: 9-19-01

PERMIT NO. 15234

Inspected by: Jr Wade
Environmental Health Specialist
SR