

02-53749

NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15197

OPERATIONS PERMIT

Name: (owner) JAY GRITZ New Installation Septic Tank
 Property Location: SR# 1121 Ray Rd Repairs Nitrification Line
 Subdivision _____ Lot # _____
 TAX ID# _____ Quadrant # _____
 Contractor: OTIS STRICKLAND Registration # _____

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface No. of exact length width of depth of
 Drainage Field ditches 1 of each ditch 300 ft. ditches 3 ft. ditches 18-24 in.
 French Drain: _____ Linear feet

Date: 5/29/02
 Inspected by: [Signature]
 Environmental Health Specialist

PERMIT NO. 18981

