

02-5-4329

H NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15196

OPERATIONS PERMIT

Name: (owner) STEVE LEE ☒ New Installation ☒ Septic Tank
Property Location: SR# 2047 HAYES RD ☐ Repairs ☒ Nitrification Line
Subdivision AMY T LEE Lot # _____
TAX ID# _____ Quadrant # _____
Contractor: OTIS STRICKLAND Registration # _____
Basement with Plumbing: ☐ Garage: ☐
Water Supply: ☐ Well ☒ Public ☐ Community
Distance From Well: 100 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☒ Conventional ☐ Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface No. of exact length width of depth of
Drainage Field ditches 4 of each ditch 75 ft. ditches 3 ft. ditches 12-18 in.
French Drain: _____ Linear feet

PERMIT NO. 19117

Date: 5/20/02
Inspected by: [Signature]
Environmental Health Specialist

