

025-4438

NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15168

OPERATIONS PERMIT


Name: (owner) Quail Run Homes / B. West New Installation Septic Tank
 Property Location: SR# 1201 Repairs Nitrification Line
 Subdivision VISTA Ridge Lot # C
 TAX ID# _____ Quadrant # _____
 Contractor: J. Fandloth Registration # _____

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field: No. of ditches 1 exact length of each ditch 240 ft. width of ditches 3 ft. depth of ditches 18 2/4 in.
 French Drain: _____ Linear feet

PERMIT NO. 19061 Date: 5-7-02
 Inspected by: Jon Lars
 Environmental Health Specialist



VISTA Ridge Home

SR
1201