

To: Joe West

HARNETT COUNTY HEALTH DEPARTMENT IMPROVEMENT PERMIT

No 12180

From: James S.

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) JAMES R. Bradford New Installation Septic Tank
Property Location: SR# 1141 Repairs Nitrification Line

bed
on
n

Subdivision Heather Brooks Est. Ph 3 Lot # 21

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: .53 AC

Basement with Plumbing: Garage: NOTE Change In

Water Supply: Well Public Community House & DRIVE Location

Distance From Well: _____ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 270 ft. width of ditches 3 ft. depth of ditches 18.24 in.

French Drain Required: _____ Linear feet


Date: 6-20-97

This permit is subject to revocation if site plans or intended use change.

Signed: Joe West
Environmental Health Specialist

VOID AFTER 5 YEARS NOTE Change In house And DRIVE location
House is 90' from front Property Line & is 15' from Lot 21/22
Property Line Drive is to be Along property Line
Lot 22 is 15' wide max.

STUB out Plumbing shallow 18-24" Dth
Dyath Follow contour maintain
175' All required setbacks



PL