


SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-4	0-8	0-20"	0-20										
TEXTURE GROUP	.1941(A)(1)	SL	SL	SL	SL										
CONSISTENCE	.1941	VFR	VFR	VFR	VFR										
STRUCTURE	.1941(A)(2)	G	G	S	C										
MINERALOGY	.1941(A)(3)	NS/NP	NS/NP	NS/NP	NS/NP										
HORIZON 2 DEPTH		4-32"	8"	20"-24"	20"-34"										
TEXTURE GROUP	.1941(A)(1)	SC+M	SC+M	SL	SL										
CONSISTENCE	.1941	FR	FI	FR	FR										
STRUCTURE	.1941(A)(2)	SBK	SBK	SBK	SBK										
MINERALOGY	.1941(A)(3)	S/S	V/M	S/S	S/S										
HORIZON 3 DEPTH				24"	34"										
TEXTURE GROUP	.1941(A)(1)			SL	SL										
CONSISTENCE	.1941			FR	FR										
STRUCTURE	.1941(A)(2)			SBK	SBK										
MINERALOGY	.1941(A)(3)			S/P	S/P										
HORIZON 4 DEPTH															
TEXTURE GROUP	.1941(A)(1)														
CONSISTENCE	.1941														
STRUCTURE	.1941(A)(2)														
MINERALOGY	.1941(A)(3)														
SOIL WETNESS	.1942	24"	20"	20"											
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/1956														
CLASSIFICATION	.1948	P3	U5	P3	TS										
LONG TERM ACCEPTANCE RANGE	.1955	.3		.3	.3										



4 x 100'
18" DEEP



2010

15200

96



117.39
 (11.23A)
 2542

77


(15.78A)
 4188

ROLLING SPRINGS
 WATER COMPANY
 (3.66A)
 8035

(17)
 78A)
 343

(1.31A)
 0608

76



ORZU