

IMPROVEMENT PERMIT

03-5-5146

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) K. Arnold Corp Judith Swearingen New Installation Septic Tank

Property Location: SR# HWY 24 Repairs Nitrification Line

Subdivision Heritage Village Lot # G-14

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 (28x58) Lot Size: 21,291 sq ft

Basement with Plumbing: Garage: Must meet onsite

Water Supply: Well Public Community

Distance From Well: 50 min ft. Before Installing

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other Pump to Conventional

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 50 ft. width of ditches 3 ft. depth of ditches 18.24 in.

French Drain Required: _____ Linear feet

Date: 8-19-97 7-23-02

This permit is subject to revocation if site plans or intended use change.

Signed: Joe Waters Joe Waters
Environmental Health Specialist

Must meet onsite Before Installing

18.24" Ditch Depth

Follow contours

Lines start

75' from

Property


Line

Connect. to

one line

MAY USE

one line



**HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT**

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 12527. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent KilArnold Corp Judith Swenee

Name: _____ Telephone # _____

Address: _____

Property Location: SR # HWY 24 Road Name _____

New Installation Repair _____ Septic Tank Nitrification Lines

Subdivision Heritage Village Lot # 6-14

Number of Bedrooms Proposed: 3 (28x58) Lot size: 21,291 sq ft

Basement _____ With Plumbing _____ Without Plumbing _____

Water Supply: Well _____ Public Minimum Well Setback: _____ ft.

Type of System: Conventional _____ Other

Tank Volume: Septic Tank 1000 gallons Pump Chamber 1000 gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 4 Length of lines 50

Width of ditches 3 ft. Depth of ditches 18-24 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: [Signature] Date: 8-13-97

(Revised 2/96)CNSTRCT.WPD [Signature] 7-23-02