

# OPERATIONS PERMIT 03-5-5293

Name: (owner) Bernice Simpson  New Installation  Septic Tank  
 Property Location: SR# 1111  Repairs  Nitrification Line  
 Subdivision \_\_\_\_\_ Lot # 1  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: L. Sharp Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:   
 Water Supply:  Well  Public  Community  
 Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
 Size of tank: Septic Tank: 600 gallons Pump Tank: \_\_\_\_\_ gallons  
 Subsurface Drainage Field No. of ditches 2 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18 1/2 in.  
 French Drain: \_\_\_\_\_ Linear feet

PERMIT NO. 19566 Date: 9-10-02  
 Inspected by: Jamu Wilber Lane Environmental Health Specialist

