

03-5-5545

# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) CHAMPLIN, EDWARD R.  New Installation  Septic Tank  
Property Location: SR# Hwy 24  Repairs  Nitrification Line

Subdivision THOMAS BURSON STYERS Lot # C

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: 1.28AC

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons


Subsurface Drainage Field No. of ditches 1 exact length of each ditch 240 ft. width of ditches 3 ft. depth of ditches 24-30 in.

French Drain Required: \_\_\_\_\_ Linear feet

Date: 4/21/07  
Signed: [Signature] ES (OLIVER TOLKSDORF)  
Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

- \* MAINTAIN ALL SETBACKS
- \* MUST MEET ONSITE PRIOR TO INSTALLATION
- \* START DRAIN 7' DEEP
- \* SURFACE WATER MUST BE DIVERTED FROM DRAINFIELD.



HARNETT COUNTY HEALTH DEPARTMENT  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department, Improvement Permit # 20057. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

CHAMPLIN EDWARD R 919-498-3886  
Name Telephone#

87 STYERS LN. CAMERON NC 28326  
Address

HWY 24 \_\_\_\_\_  
Property Location SR# Road Name

THOMAS BURTON STYERS C 3 1.28AC  
Subdivision Lot # # Bedrooms Proposed Lot Size

**TYPE OF SYSTEM**

New Installation  Repair  Septic Tank  Nitrification Lines

Conventional  Other \_\_\_\_\_

Basement  With Plumbing  Without Plumbing

Water Supply:  Well  Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber \_\_\_\_\_ gal

**NITRIFICATION FIELD SPECIFICATIONS**

Number of fields 1 # of lines per field 1 Length of lines 240 Ft.

Width of ditches 3 ft. Depth of ditches 24-30 inches

French Drain: Linear feet required 250 Depth of gravel 72"

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

[Signature] RS 4/21/03  
Signature of Authorized Agent for Harnett County of Harnett Date