

03-5-5749

NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15464

OPERATIONS PERMIT

Name: (owner) (Freund) Freund, Michael New Installation Septic Tank
 Property Location: SR# 2039 Repairs Nitrification Line
 Subdivision Carroll Lot # 1
 TAX ID# _____ Quadrant # _____
 Contractor: Larry Shupe Registration # _____

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 100 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain: _____ Linear feet

Date: 11/25/02

PERMIT NO. 19804

Inspected by Jay M. Lewis R.S.
Environmental Health Specialist

